

STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

906 Columbia Street SW • P.O. Box 48300 • Olympia, Washington 98504-2525 • (360) 725-2967

STATE BUILDING CODE INTERPRETATION NO. 00-07

CODE: 1997 State Regulations for Barrier-Free Facilities

SECTION: WAC 51-40, Section 1103.2.2

QUESTION: Would a two-story office building (Group B) with less than 3,000 square feet

per floor over a basement parking garage (Group S, Division 3) of

approximately 6,000 square feet required to have an accessible route of travel connecting the three floor levels? Accessible parking is provided on the first

ground level and not in the parking garage.

ANSWER: Yes.

SUPERSEDES: None

REQUESTED BY: City of Kirkland