

STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

906 Columbia Street SW • P.O. Box 48300 • Olympia, Washington 98504-2525 • (360) 725-2967

STATE BUILDING CODE INTERPRETATION NO. 00-15

- CODE: 1997 Washington State Mechanical Code
- **SECTIONS:** Chapter 11, Refrigeration
- QUESTIONS: Chapter 11 of the UMC has been replaced and rewritten in its entirety. As amended, Chapter 11 makes no reference to labeling requirements for refreigerant piping. Does the code require labeling of such piping?
- ANSWERS: Chapter 11 references ASHRAE Standard 15. Standard 15 does require labeling of refrigerant piping.
- SUPERSEDES: None
- **REQUESTED BY:** City of Renton