## STATE BUILDING CODE INTERPRETATION NO. 02-06

**CODE:** 2000 Washington State Energy Code

**SECTIONS:** 1110 Purpose and Intent; and 1301 Scope

**QUESTION:** Are enclosures for ATM machines, which provide heating and/or

cooling in order to keep the equipment within acceptable temperature limits, required to meet the provisions of the Washington State Energy

Code?

**ANSWER:** Yes. Buildings, or portions thereof, that house ATM machines are not

exempt.

**SUPERSEDES:** None

**REQUESTED BY:** Department of Labor and Industries