



STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

128-10th Avenue SW • P.O. Box 42525 • Olympia, Washington 98504-2525
(360) 725-2966 • fax (360) 586-9383 • e-mail sbcc@cted.wa.gov • www.sbcc.wa.gov

STATE BUILDING CODE INTERPRETATION NO. 08-01

CODE: 2006 International Building Code

SECTION: 2902.2.1, 3409.7

QUESTIONS: A new warehouse storage facility is being constructed to provide additional storage for existing operations. Restroom facilities will be provided by existing facilities in an adjacent building per Section 2902.2.1. Would the existing facilities be required to be brought into full compliance with ICC/ANSI A117.1-2003?

ANSWERS: **No. The existing facilities would not have to be brought into compliance unless there was an alteration or addition to the main building, or the new space contains an area of primary function.**

SUPERSEDES: None

REQUESTED BY: Yakima County