



STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

128-10th Avenue SW • P.O. Box 42525 • Olympia, Washington 98504-2525
(360) 725-2966 • fax (360) 586-9383 • e-mail sbcc@cted.wa.gov • www.sbcc.wa.gov

STATE BUILDING CODE INTERPRETATION NO. 08-05

CODE: 2006 Washington State Energy Code

SECTION: Table 11-1, Economizer Compliance Options for Mechanical Alterations

QUESTION: Table 11-1 references NPLV values in Tables 14-1K, 14-1L and 14-1M in footnotes 13 and 14. These tables are not present in the WSEC, and the WSEC does not reference NPLV values in any other tables. What values should be used?

ANSWER: **The reference in footnotes 13 and 14 should be for the IPLV values found in Table 14-1C.**

SUPERSEDES: None

REQUESTED BY: City of Lacey