

## STATE OF WASHINGTON

## STATE BUILDING CODE COUNCIL

128-10th Avenue SW • P.O. Box 42525 • Olympia, Washington 98504-2525 (360) 725-2966 • fax (360) 586-9383 • e-mail sbcc@cted.wa.gov • www.sbcc.wa.gov

## STATE BUILDING CODE INTERPRETATION NO. 08-07

**CODE:** 2006 International Building Code

**SECTION:** 2902.3.1, Separate Facilities

2903.4.1, Number of Drinking Fountains

**QUESTIONS:** 1. How is the number of persons served referenced in Section

2902.3.1 determined?

2. What occupant load table is used to determine the occupant load

referenced in Section 2903.4.1?

ANSWERS: 1. Chapter 29 is designed to be a stand-alone section of the code.

Fixture counts and occupancy determinations are intended to

be calculated using the figures provided in Table 2902.1.

2. The occupant load numbers found in Table 2902.1 for the appropriate occupancy classification should be used to

calculate the number of drinking fountains required. See

answer 1, above.

**SUPERSEDES:** None

**REQUESTED BY:** City of Spokane Valley