



STATE OF WASHINGTON

**STATE BUILDING CODE COUNCIL**

**Department of General Administration**

*210 11th Avenue SW • P.O. Box 41011 • Olympia, Washington 98504-1011  
(360) 902-7293 • fax (360) 586-0493 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc*

**STATE BUILDING CODE INTERPRETATION NO. 11-13**

**CODE:** 2009 WSEC

**SECTION:** 1203, Energy Metering

**QUESTION:** Section 1203 refers to new or replacement systems or equipment that exceed the thresholds in Table 12-1 or Table 12-2. The systems or equipment that exceed the threshold must comply with Section 1201. Section 1201 refers to whole building energy supply sources and a requirement for a totalizing meter for those sources. Section 1202 contains the requirements appropriate for the thresholds listed in Table 12-1 and Table 12-2. Do new or replacement systems or equipment referenced in Section 1203 require conformance with requirements in both Section 1201 and 1202?

**ANSWER:** **Yes. Section 1201 General, scopes all of Chapter 12. Where Section 1201 applies, all of Chapter 12 applies. See also Interpretation No. 11-10.**

**SUPERSEDES:** None

**REQUESTED BY:** City of Shoreline