



STATE OF WASHINGTON

**STATE BUILDING CODE COUNCIL**

**Department of General Administration**

*210 11th Avenue SW • P.O. Box 41011 • Olympia, Washington 98504-1011  
(360) 902-7293 • fax (360) 586-0493 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc*

**STATE BUILDING CODE INTERPRETATION NO. 11-14**

**CODE:** 2009 WSEC

**SECTION:** 1132, Alterations and Repairs; 1203, Metering

**QUESTION:** If an alteration or repair meets all the requirements of Section 1132 (1132.1; 1132.2; 1132.3), are the master and submetering requirements of Chapter 12 also required?

**ANSWER:** **The intent for existing buildings, governed by Section 1130, is to apply the requirements of Section 1130, and in addition, for new and replacement systems or equipment that exceed the thresholds of Table 12-1 or Table 12-2 to also apply the requirements of Chapter 12.**

**SUPERSEDES:** None

**REQUESTED BY:** City of Shoreline