



STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

Department of General Administration

*210 11th Avenue SW • P.O. Box 41011 • Olympia, Washington 98504-1011
(360) 902-7293 • fax (360) 586-0493 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc*

STATE BUILDING CODE INTERPRETATION NO. 11-15

CODE: 2009 WSEC

SECTION: Table 12-1, Energy Source Meter Thresholds

QUESTION: Is the threshold for electrical service referenced in the table the “calculated load”, which is the connected load with National Electrical Code (NEC) diversity factors applied? If not, what is the specific figure of merit in this determination?

ANSWER: **Yes.**

SUPERSEDES: None

REQUESTED BY: City of Shoreline