

Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504 (360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc

STATE BUILDING CODE INTERPRETATION NO. 14-07

CODE: 2012 Washington State Energy Code, Commercial

SECTION: Definition – Semi-heated Building

QUESTION: A storage facility is required to maintain a minimum rate of

ventilation, with a heating system capacity over 8 BTU-h/sf needed to temper the required ventilation air to above freezing. Is this space

eligible to be designated as semi-heated?

ANSWER: No, the building exceeds the maximum heating system output.

SUPERSEDES: None

REQUESTED BY: Pierce County