



Washington State Building Code Council

Improving the built environment by promoting health, safety and welfare

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504
(360) 407-9280 • fax (360) 586-5366 • e-mail sbcc@ga.wa.gov • www.ga.wa.gov/sbcc

STATE BUILDING CODE INTERPRETATION NO. 14-15

CODE: 2012 Washington State Energy Code, Commercial

SECTION: Section C405.2.1 Manual lighting controls
Section C405.2.2 Additional lighting controls
Section C405.2.3 Specific Application
Controls

QUESTION: Are light fixtures that are covered under Section C405.2.3 also required to comply with all applicable requirements in Section C405.2.1 and C405.2.2?

ANSWER: **No for Items 1 to 6 of Section C405.2.3. These are specific application lighting controls that are not included in the general lighting requirements sections C405.2.1 and C405.2.2; therefore, there are no applicable requirements in Section C405.2.1 and C405.2.2.**

Yes for Item 7 of Section C405.2.3. The lighting controls requirements of Sections C405.2.1 and C405.2.2 must comply with the applicable requirements in these sections.

SUPERSEDES: None

REQUESTED BY: Pierce County