



# Washington State Building Code Council

*Improving the built environment by promoting health, safety and welfare*

1500 Jefferson Street SE • P.O. Box 41449 • Olympia, Washington 98504  
(360) 407-9277 • e-mail [sbcc@des.wa.gov](mailto:sbcc@des.wa.gov) • [www.sbcc.wa.gov](http://www.sbcc.wa.gov)

## STATE BUILDING CODE INTERPRETATION NO. 18-13

**CODE:** 2015 Washington State Energy Code, Commercial

**SECTION:** Tables C407.5.1(2) and (3) – Footnote B

**QUESTION:** For mixed fuel heating systems, can the largest percentage of heating load met by a system (instead of installed output capacity) be used to determine the primary heating source?

**ANSWER:** **No. The code specifically requires the primary source to be the largest installed capacity system.**

**SUPERSEDES:** None

**REQUESTED BY:** City of Bellevue