

STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

906 Columbia Street SW • P.O. Box 48300 • Olympia, Washington 98504-2525 • (360) 725-2967

STATE BUILDING CODE INTERPRETATION NO. 98-02

CODE: 1994 State Regulations for Barrier-Free Facilities

SECTION: Section 1103, Building Accessibility

QUESTION: Are marina gangways, docks and floats exempt from State Barrier-Free

requirements?

ANSWER: Yes. Gangways, floats, and docks are not scoped as needing to be

accessible under the purview of Chapter 11, and therefore are exempt.

SUPERSEDES: None

REQUESTED BY: City of Edmonds