

STATE OF WASHINGTON

STATE BUILDING CODE COUNCIL

906 Columbia Street SW • P.O. Box 48300 • Olympia, Washington 98504-2525 • (360) 725-2967

STATE BUILDING CODE INTERPRETATION NO. 98-08

- **CODE:** 1994 Uniform Fire Code
- **SECTION:** 5201.1 Exception
- **QUESTION:** Under what conditions can a permit application for fleet fueling, as allowed by the exception to UFC Section 5201.1, be denied?
- ANSWER: A permit for fleet fueling can be denied when not approved by the chief. If approved by the chief, a permit can be denied if any of the conditions listed in the exception to UFC Section 5201.1 or the conditions of UFC Section 7904.5.4.2.2.1 are not met.

SUPERSEDES:NoneREQUESTED BY:City of Kirkland