

area in the immediate vicinity of the bedrooms in dwelling units or sleeping units and on each level of the dwelling. The carbon monoxide alarms shall be listed as complying with UL 2034 and be installed and maintained in accordance with NFPA 720-2012 and the manufacturer's instructions.

Exceptions:

1. For other than R-2 occupancies, the building does not contain a fuel-burning appliance, a fuel-burning fireplace, or an attached garage; or
2. Sleeping units or dwelling units in I and R-1 occupancies and R-2 college dormitories, hotel, and DSHS licensed boarding home and residential treatment facility occupancies which do not themselves contain a fuel-burning appliance, or a fuel-burning fireplace, or have an attached garage, need not be provided with carbon monoxide alarms provided that:
 - a. The sleeping unit or dwelling unit is not adjacent to any room which contains a fuel-burning appliance, a fuel-burning fireplace, or an attached garage; and
 - b. The sleeping unit or dwelling unit is not connected by duct work or ventilation shafts with a supply or return register in the same room to any room containing a fuel-burning appliance, a fuel-burning fireplace, or to an attached garage; and
 - c. The building is provided with a common area carbon monoxide detection system.
3. An open parking garage, as defined in Chapter 2 of the *International Building Code*, or enclosed parking garage ventilated in accordance with Section 404 of the *International Mechanical Code* shall not be considered an attached garage.

908.7.1 Carbon monoxide detection systems. Carbon monoxide detection systems, that include carbon monoxide detectors and audible notification appliances, installed and maintained in accordance with this section for carbon monoxide alarms and NFPA 720-2012 shall be permitted. The carbon monoxide detectors shall be listed as complying with UL 2075.

908.7 Carbon monoxide alarms. Group I or Group R occupancies shall be provided with single station carbon monoxide alarms installed outside of each separate sleeping

(Insert Facing Page 226)