

# SUMMARY OF STATE AMENDMENTS November 15, 2017

## 2015 IEBC Amendments to WAC 51-50

November 3, 2017

	Section	2015 amendments	Sub sections / adoption notes	Commentary
1	101.4.2	Buildings previously occupied	Text change	2018 text same a 2015
2	101.6	Appendices	Includes Appendix A Guidelines for the Seismic Retrofit of Existing Buildings	2018 text same a 2015
3	403.1	General	Adds Exception 3.	2018 text changed from 2015 <b>This is now Section 503.1. State amendment should be retained and moved to 503.1.</b>
4	407.1	Conformance	Text change	2018 text changed from 2015 <b>This is now Section 506.1 and titled "Compliance"</b>
5	409.1	Conformance	Text change	Not in 2018 <b>Section should be changed to 508 "Moved Buildings" and be Section 508.1</b>
6	410.6	Alterations	Modified Exception 4	Not in 2018 <b>This language is now in IEBC Section 305.6. Recommend repeal</b>
7	705.1.5	Dining Areas	Section not adopted	Not in 2018 <b>If this is desired to be retained, it should be moved to Section 305.7.1</b>
8	705.1.9	Toilet rooms	Additional text	The wording of this additional text proved problematic for Moses Lake - Not in 2018 <b>Recommend moving to Section 305.7.2 and adding language "The minimum number of single user toilet rooms shall not be reduced"</b>
9	708.1	Minimum requirements	Text change	707.1 in 2018 - 2018 text same a 2015
10	811.1	Minimum requirements	Text change	810 in 2018 - 2018 text same a 2015
11	906.2	Type B dwelling or sleeping units	Eliminate exception	Not in 2018 <b>Language is now in Section 308.8 and the non-adopted exception is no longer in the code. Recommend repeal</b>
12	907.4.1	Evaluation and analysis	Additional text	Not in 2018 <b>Substantial changes in the 2018 IEBC. Similar provisions now found in Section 906. Recommend analysis to see if amendment is still necessary</b>
13	908.1	Minimum requirements	Text change	907.1 in 2018 - 2018 text same a 2015
14	1201.1	Scope	Text change	2018 text same a 2015
15	1203.9	Stairway railings	Changed "Grand" to "Historically Significant"	2018 text same a 2015
16	1204.1	Accessibility requirements	Text change	Not in 2018 <b>Language is now in Section 305.9. Recommend review of amendment to see if it is still needed</b>
17	1205.10	One-hour fire-resistant assemblies	Text addition	1204.10 in 2018 - 2018 text same a 2015
18	1205.14	Natural light	Text change	1204.14 in 2018 - 2018 text same a 2015
19	1301.1	Scope	No change	Interpretation 16-05 amends definition of relocatable to exclude "portables" - 2018 text changed from 2015
20	1301.2	Conformance	Text change	2018 text changed from 2015
21	1302	Requirements	Section not adopted	2018 text changed from 2015

DES\CPRM\SBCC\TAGS 2016-2018\IBC, IEBC\IEBC\IEBC 2015 amendments commentary.docx