


# Preliminary Cost Benefit Analysis for the 2021 Washington State Energy Code, Commercial Provisions

The legislature finds making homes, businesses, and public institutions more energy efficient will save money, create good local jobs, enhance energy security, reduce pollution that causes global warming, and speed economic recovery while reducing the need to invest in costly new generation. The State Energy Code Act, RCW 19.27A, sets forth the statutory authority and goals for the adoption and amendment of the Washington State Energy Code. The primary goals are to construct increasingly energy efficient homes and buildings that help achieve the broader goal of building zero fossil-fuel greenhouse gas emission homes and buildings by the year 2031 [RCW 19.27A.020 (2)(a)], any amendments must increase the energy efficiency of typical newly constructed nonresidential buildings [RCW 19.27A.025(1)(a)], and amendments shall incrementally move towards achieving a seventy percent reduction in annual net energy consumption by 2031 [RCW 19.27A.160]. To achieve the required seventy percent reduction, the Washington State Building Code Council (SBCC) established two models for measuring incremental change. One was to target an 8.75 percent reduction each three-year code cycle compared to the 2006 code. The other pathway is a 14 percent reduction over the previous code.



Based on the report of the progress made with the 2018 code towards the 70 percent reduction, a 19 percent reduction over the previous code was identified to place the commercial portions of the code back on track to attain the targeted reduction for the 2021 code. Stakeholders were asked to submit proposals to help attain this reduction goal.

Additionally, the Clean Buildings Act [RCW 19.27A.210] requires large nonresidential building owners in Washington state to demonstrate building performance in compliance with an established energy use intensity (EUI) target. Currently there are incentives for those buildings showing voluntary early compliance. However, compliance will be mandatory beginning in 2026. Several concerns were expressed that if the Washington State Energy Code did not meet the reduction goals, it could cause newer building stock to be out of compliance with the Clean Buildings Act, requiring retroactive upgrades to building systems.

The Residential Portion of the energy code covers residential buildings including single family homes, townhouses, and multi-family dwelling unit buildings that are three stories and less. The Commercial Portion of the energy code, which is the topic of this cost benefit analysis, covers all non-residential buildings, residential dwelling unit buildings that are four stories and more, and all residential sleeping unit buildings regardless of the number of stories.

The International Energy Conservation Code is the base document for the development of the Washington State Energy Code and this national model code is updated every three years. Those updates that further the statutory goals set forth in RCW 19.27A are integrated with the existing WAC 51-11C language and published as a basis for stakeholders to submit code change proposals.

The Washington State Building Code Council (SBCC) filed the Preproposal Statement of Inquiry to initiate the development of the 2021 Washington State Energy Code, Commercial Provisions, as adopted through WAC 51-11C, on March 23, 2021. In considering amendments to the state energy code, the Council established and consulted with a technical advisory group (TAG) including representatives of appropriate state agencies, local governments, general contractors, building owners and managers, design professionals, utilities, and other interested and affected. On April 1, 2021, the SBCC opened a 60-day submittal period for proposals for the 2021 Washington State Energy Code, Commercial provisions.

The Council has adopted a definition of cost-effectiveness based on RCW 39.35 as recommended by Department of Commerce. A guide on how to evaluate cost-effectiveness is therefore defined by the Council as a code change that has a net present savings over a 50-year life-cycle of a building utilizing the Life Cycle Cost Tool (LCCT) as developed by the Washington State Office of Financial Management (OFM). The methodology of the LCCT is based on the NIST Handbook 135 methodology and utilizes specific inputs as determined by the Council with guidance from the Washington State Department of Commerce<sup>1</sup>. The cost effectiveness analysis uses the average useful life years from Appendix 7 of the BOMA Preventive Maintenance Guidebook for all building components that are evaluated<sup>2</sup>. An alternate method of cost effectiveness analysis or determining average useful life years of building components may be applied. Each code change submitted that is not editorial or explanatory is required to include this analysis.

The TAG was also tasked with reviewing the proposals received, identifying pros and cons and whether it helped achieve the broader goals of energy savings and emission reduction. The TAG also discussed whether modifications were needed to ensure the provisions were correlated with other requirements,

---

<sup>1</sup> <http://www.ofm.wa.gov/budget/facilities/costanalysis.asp>

<sup>2</sup> <https://icap.sustainability.illinois.edu/files/projectupdate/2289/Project%20Lifespan%20Estimates.pdf>

technically feasible, commercially available, and cost-effective to building owners and tenants, or if changes were necessary to mitigate any disproportionate impact on small business.

161 proposals were submitted during the two-month submittal period. After hundreds of hours of discussions, the TAG recommended that 118 proposals move forward into the rulemaking process. Most of these proposals are exempt from the cost benefit analysis requirement of 34.05.328 as they are editorial or provide additional clarity to existing rules. Additionally, changes coming from the national model code process (International Energy Conservation Code) are also exempt from the requirements of RCW 34.05.328 and not addressed here. Ultimately 23 proposals were identified as having more than a minimal cost impact. Thirty-seven proposals were editorial. The remaining 60 proposals were either clarifying requirements, correlating code requirements, or had minimal impact. Those with minimal impact are highlighted in Table 1.

**TABLE 1**  
**Code Change Proposals with Minimal Economic Impact**

<b>Code Change</b>	<b>Section/Description</b>	<b>Cost/Energy Savings</b>
<a href="#">21-GP1-159</a>	<b>C402.2.8/C402.2.9:</b> New requirement detailing control of thermal bridging at concrete balconies and fenestration frames to reduce heat loss.	Estimated construction cost of \$1.33 per square foot or \$1000 per dwelling unit for those apartments/dwellings with cantilevered concrete balconies. Estimated annual energy savings of 0.02 kBtu per square foot per balcony, or a savings of \$11.79 per year per balcony in energy cost.
<a href="#">21-GP1-161</a>	Table C402.4: Fenestration U-values are reduced, while allowing a slighter higher value for operable window for a greater range of choice. The fenestration U-values for increased allowable fenestration area is adjusted accordingly.	This proposal reduces heat loss through fenestration, the most significant heat loss for building envelopes. The higher-performance fenestration is moderately more expensive than conventional, a cost that is likely to moderate as the new standard becomes commonplace. The estimated construction cost is \$0.09 per square foot, or \$69 per dwelling unit, with estimated annual energy savings of 0.016 kBtu per square foot, or 12.4 kWh/kBtu per dwelling unit.
<a href="#">21-GP1-108</a>	<b>C402.5.2:</b> Removes the exception allowing the air leakage rate to be exceeded with a report of corrective action taken.	Currently, if a building fails the envelope leakage test, corrective action is to be taken but verification is not required. Requiring retest and correction action measures be taken until the required air leakage rate is met encourages best practices to be implemented during construction. This proposal only economically impacts projects that fail to meet the required air leakage rate.
<a href="#">21-GP1-104</a>	<b>C402.5.5:</b> Align combustion air duct insulation requirements with outside air requirements.	Initial capital costs will be more expensive for the insulation material and labor. Estimate of construction cost is less than \$0.01 per square foot, with an estimated energy savings of 10.6 kBtu per square foot, based on a 50,000 square foot building.

Code Change	Section/Description	Cost/Energy Savings
<a href="#">21-GP1-163</a>	<b>C403.2.4/C404.13:</b> Decrease the size threshold for requiring variable speed drive for fan and pump motors.	The estimated incremental construction cost is \$0.04 per square foot. With an estimated 4 VFD motors in a 10,000 square foot building. Estimated energy savings of \$0.10 kWh per square foot.
<a href="#">21-GP1-166</a>	<b>C403.3.7:</b> A new section and table are added to incorporate requirements from ASHRAE 90.1 limiting the flow rate in critical circuits of hydronic systems to minimize flow resistance.	The requirements ensure hydronic system piping is designed appropriately and may result in larger pipe sizes for projects that would have otherwise had under-sized pipes. Pumping energy costs will be reduced. Estimated cost of construction is \$0.02 per square foot based on a 100,000 sf building, with an estimated annual energy savings of 0.6 kBtu per square foot.
<a href="#">21-GP1-167</a>	<b>C403.4.12:</b> Requires pressure independent control valves where the flow rate over coils is over 5 gallons per minute.	PICVs play an important role in reducing energy consumption while maintain building temperature at optimal setpoints, and are capable of reducing HVAC energy use more than 20%. Estimated construction cost is \$0.01 per square foot, with an estimate of annual energy savings of 0.05 kWh per square foot based on a 100,000 sf building.
<a href="#">21-GP1-191</a>	<b>C403.7.5:</b> Requires variable frequency drives on all motors over 5 hp in parking garage and loading dock ventilation systems.	There is an increased first cost for the VFD controller. ASHRAE 90.1 addendum d states that all VAV system fans are required to have VFD so no economic analysis is required. Title 24 reports that the estimated incremental cost is \$2500 plus \$600 in installation costs for each 10,000 cfm of garage exhaust. The average garage has 6 hp per 10,000 cfm. Annual energy saving is estimated at 2818 kWh per hp.
<a href="#">21-GP1-170</a>	<b>C403.7.6.2:</b> Increases the enthalpy recovery ratio from 50 to 60 percent for other than R-2 occupancies.	There is a slight increase in cost of ERV, with a 20% increase in recovered energy. Estimated construction cost is \$0.10 per square foot, with an estimated annual energy savings of 1 kWh per square foot.
<a href="#">21-GP1-174</a>	C404.6.1: Requires thicker insulation for service water heating storage tanks designed for storage temperatures over 130 degrees.	The estimated incremental construction cost is \$0.01 per square foot, with an estimated annual energy savings of 0.1 kBtu per square foot.
<a href="#">21-GP1-175</a>	C404.7.1: Requires service water circulation systems with multiple risers or zones and variable flow circulation pumps to use self-actuating thermostatic balancing valve to	The estimated construction cost is \$0.002 per square foot, based on a 100,000 square foot building. The estimated annual energy savings are 0.2 kWh per square foot.

Code Change	Section/Description	Cost/Energy Savings
	optimize flow of hot water to the different zones.	
<a href="#">21-GP1-182</a>	C404.7.1.2: Requires electronically commutated motors for all service water heating circulation pumps.	In service water heating systems, circulation pumps with electronically commutated motors (ECM) offer up to 20% annual energy savings compared to circulation pumps with standard induction motors. There is an estimated \$250 incremental cost per pump based on manufacturer data, with a net present LCCA savings of \$677, with a 30% reduction in carbon emissions.
<a href="#">21-GP1-176</a>	C404.7.3.1: New section to require thicker insulation for service water system piping in the circulation loop.	Estimated construction cost is \$0.002 per square foot with an estimated annual energy savings of 0.1 kBtu per square foot.
<a href="#">21-GP1-177</a>	C404.11.1: Requires heat pump water heaters on heated pools over 2000 gallons	Cost for pool heaters is not related to size of building. A heat pump pool heater costs approximately \$1000 more than an electric resistance heater. Since pools are frequently used in warmer weather, the effective heat pump COP can be considerable higher than the rated COP at 50°F, reducing power consumption by as much as 80%. Specific savings will depend on frequency of use and size of pool.
<a href="#">21-GP1-178</a>	<b>C405.2:</b> Lighting control requirements, including high end trim, for luminaire level lighting controls; requirement for LLLC in open plan office areas larger than 5,000 square feet	The requirement to conduct high-end trim will increase installation costs and deliver significant energy savings. This is an optional path, however. Task tuning is estimated at \$0.06 per square foot. Assuming 80 square feet per fixture, the cost is approximately \$5.28 per fixture, with an energy savings of 12.5kWh per year per fixture.
<a href="#">21-GP1-125</a>	<b>C405.2.7.3:</b> Decreases the lamp wattage for luminaires requiring activity sensor control.	Costs and savings are estimated from the <a href="#">Nonresidential Outdoor Lighting Controls</a> report from the CASE Initiative. Incremental construction cost increase was estimated at \$72.30 for the activity sensor. The estimated annual savings is \$145, with a 24% decrease in carbon emissions.
<a href="#">21-GP1-98</a>	<b>C405.3:</b> Increases the efficiency requirements for lighting used for plant growth and maintenance.	The proposal represents a 6.3% improvement for greenhouses and a 18.8% savings for indoor growing applications. Indoor growing facilities can vary in size, but the exception threshold can be used as an example of savings. US DOE estimates that indoor growing facilities use

Code Change	Section/Description	Cost/Energy Savings
		lighting 5,200 to 6,570 hours per year. That results in a savings of 39-51 MWh per year for the smallest system subject to the requirement. DOE also estimates 2,000 hours of runtime in greenhouses, which would result in 5 MWh savings per year for the smallest system subject to the requirements. These will result in substantial operating savings for growers, particularly for operations that also require cooling to offset heat gains from lighting loads.
<a href="#">21-GP1-137</a>	<b>C405.13:</b> Adds uninterruptible power supply requirements for computer rooms based on Energy Star requirements.	Incremental costs were found to be \$112/kWh for high efficiency UPS systems and were converted to \$/sq.ft. based on a 500 square foot room (the threshold for which a computer room does not qualify as a data center. The cost estimate is \$0.22 per square foot, with an estimated energy savings of 6.5 kWh per square foot.
<a href="#">21-GP1-101</a>	<b>C408.1:</b> Lowers the threshold for commissioning requirements.	Typical commercial building commissioning cost is \$1.00 per square foot, resulting in an energy cost savings of 15% annually. Simple energy saving payback of 7-years Assuming occupant productivity cost improvement simple payback time is cut in half.

Code proposals identified as significant are identified in Table 2, and are detailed below.

**TABLE 2**  
**Code Change Proposals Marked as Significant Impact**

<u>Proposal Number</u>	<u>Subject</u>	<u>Proponent</u>	<u>Initial Cost Benefit Analysis</u>
<a href="#">21-GP1-103</a>	Space Heating Proposal	Jonny Kocher, RMI	<a href="#">Proponent’s Cost Benefit Analysis</a>
<a href="#">21-GP1-136</a>	Heat Pump Water Heating	Jonny Kocher, RMI	<a href="#">Proponent’s Cost Benefit Analysis</a>
<a href="#">21-GP1-179</a>	Electrical Receptacles at Gas Appliances	Duane Jonlin, City of Seattle	<a href="#">Proponent’s Cost Benefit Analysis</a>
<a href="#">21-GP1-78</a>	On-Site Renewable Energy	Mark Frankel, Ecotope	<a href="#">Proponent’s Cost Benefit Analysis</a>
<a href="#">21-GP1-207</a>	CMU Walls Table Footnote Modification	Luke Howard, Commerce	<a href="#">Proponent’s Cost Benefit Analysis</a>

<b>Proposal Number</b>	<b>Subject</b>	<b>Proponent</b>	<b>Initial Cost Benefit Analysis</b>
<a href="#">21-GP1-208</a>	Elimination of CMU Wall Footnote	Luke Howard, Commerce	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-69</a>	HVAC TSPR	Michael Rosenberg PNNL	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-95</a>	Indoor Horticulture Dehumidification	Sean Denniston, New Buildings Institute	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-99</a>	DR Water Heaters	Sean Denniston, New Buildings Institute	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-193</a>	Compressed Air	Mike Kennedy	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-180</a>	Reduce Threshold for LPA Compliance on Remodels	Duane Jonlin, City of Seattle	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-139</a>	Boiler Controls	Nicholas O'Neil, Energy 350	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-138</a>	Fan Power Allowance Tables	Nicholas O'Neil, Energy 350	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-160</a>	PTAC U-factors	Duane Jonlin, City of Seattle	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-164</a>	Include Split Systems in HP Requirement	Duane Jonlin, City of Seattle	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-133</a>	High capacity space heating boiler	Mike Kennedy	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-165</a>	60% enthalpy ERV required for DOAS, except R1/R2	Duane Jonlin, City of Seattle	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-97</a>	DR Thermostats	Sean Denniston, New Buildings Institute	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-190</a>	DCV	Mike Kennedy	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-204</a>	Exterior Building Grounds Lighting	Michael Myer, PNNL	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-198</a>	Exterior Lighting	Michael Myer, PNNL	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-146</a>	Additional Efficiency Credits	Mark Frankel, Ecotope	<a href="#">Proponent's Cost Benefit Analysis</a>
<a href="#">21-GP1-206</a>	Load Management	Reid Hart, PNNL	<a href="#">Proponent's Cost Benefit Analysis</a>

**Heat Pump Space Heating, Proposal 21-GP1-103**, adding a new section WAC 51-11C-40314 and modifying existing sections 51-11C-40702 and 51-11C-50300

**Brief Description:** Provide heat pump space heating, rather than fossil fuel or electric space heating, for all buildings. Exceptions are provided to allow electric resistance heating for small loads and as

supplementary heat. Exceptions also allow fossil fuel auxiliary heat in Climate Zone 5 under certain conditions.

**Purpose of code change:** Heat pump space heating eliminates a significant source of fossil fuel combustion in buildings and is generally two to four times more energy efficient than either fossil fuel or electric resistance heating. This proposal aligns with State policy to increase energy efficiency by 70 percent by 2031. Additionally, this proposal will significantly reduce emissions and is aligned with State policy to achieve the broader goal of building zero fossil-fuel greenhouse gas emission homes and buildings by the year 2031. According to analysis based on the data from the 2021 Washington State Energy Strategy, we need to reduce the commercial buildings sector emissions by 38 percent to keep on track to meet our 2050 climate goals. To achieve this, the State will need to quadruple the proportion of annual sales of heat pumps from 11 percent of all commercial space heating equipment in 2020 to 40 percent by 2030. To get to this increase in market penetration of heat pumps, the Washington State Energy Code should require heat pump space heating in the 2021 code cycle. See Supplemental Attachment<sup>3</sup> for further details on emissions and market penetration.

**Review Process:** The TAG spent several 6-hour meetings reviewing this proposal. It was sent back several times to be revised and reviewed by workgroups, including the proponent and key stakeholders. Through these workgroups and TAG review, modifications were suggested and made to help mitigate impact on small business. Alternative provisions were added to allow gas auxiliary heat in climate zone 5 (eastern Washington). Impact on existing buildings was mitigated; with the requirements applicable only if the entire HVAC system is replaced. Further modifications allowing more significant use of fuel gas appliances were reviewed and rejected by the TAG. These minority report opinions were forwarded to the Mechanical, Ventilation and Energy Codes Committee and the Council, along with the TAG recommendations, for review and consideration as alternate options for adoption.<sup>4</sup>

**Probable Benefits vs probable costs:** Construction costs for heat pump space heating are often, but not always, higher than for conventional natural gas or electric resistance heating. Annual energy costs for heat pumps are much lower than for electric resistance heating, but the same or slightly higher when compared with gas heating, at current rates (World Bank long term forecasts indicate an increase of over 80% in gas prices over the coming decade.) When including the Washington State social cost of carbon, heat pump space heating is more cost effective than both gas heating and electric resistance heating over the life cycle analysis horizon.

Benefits to building owners, tenants, and businesses include early alignment with the Clean Buildings Bill (to avoid future performance compliance penalties) and reduced life cycle cost (especially when considering the potential increases to the Social Cost of Carbon). Given the state's climate goals and policy, this Energy Code proposal will help ensure new assets permitted beginning July 1, 2023, will not need to be immediately retrofitted to conform with the Clean Buildings requirements.

The average net present value capital cost increase for this proposal will be around \$0.24/square foot. The average life cycle cost savings of \$0.70/square foot and \$2.70/square foot when including the social cost of carbon. See Supplemental Attachment (footnote 3) for more details.

---

<sup>3</sup> [https://sbcc.wa.gov/sites/default/files/2021-10/103\\_HP%20Space%20Heat\\_supplemental.pdf](https://sbcc.wa.gov/sites/default/files/2021-10/103_HP%20Space%20Heat_supplemental.pdf)

<sup>4</sup> [https://sbcc.wa.gov/sites/default/files/2021-07/103\\_Minority%20Report\\_Amendment%28s%29\\_072121.pdf](https://sbcc.wa.gov/sites/default/files/2021-07/103_Minority%20Report_Amendment%28s%29_072121.pdf)

---

**Heat Pump Water Heating, Proposal 21-GP1-136**, Option 2 provides a new Section C404.2.1 under WAC 51-11C-40402 and modifying sections 51-11C-40407 and 51-11C-50300, as well as adding new definitions for *Temperature Maintenance*, *Single-pass* and *Multi-pass*. If this proposal is not adopted, there also options within Section C406 that increase the number of credits required and provide credits for the installation of heat pump water heaters.

**Brief Description:** Provide heat pump water heating rather than fossil fuel or electric resistance water heating in commercial buildings. Exceptions are provided to allow electric resistance heating for hand washing facilities.

**Purpose of code change:** Heat pump water heating eliminates a significant source of fossil fuel combustion in buildings and is generally 2-4 times more energy efficient than either fossil fuel or electric resistance heating. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031. Additionally, this proposal will significantly reduce emissions, aligned with state policy to achieve the broader goal of building zero fossil-fuel greenhouse gas emission homes and buildings by the year 2031. According to analysis done on data from the 2021 Washington State Energy Strategy, we would need to reduce the commercial buildings sector emissions by 38 percent to keep on track to meet our 2050 climate goals. To achieve this, the state will need to dramatically increase the proportion of annual sales of heat pump water heaters from 2 percent of all commercial water heating equipment in 2020 to 50 percent by 2030. To get to this increase in market penetration of heat pump water heaters, the Washington State Energy Code should require heat pump water heating in the 2021 code cycle.

**Review Process:** The TAG spent several meetings reviewing this proposal, and it was sent back several times to be revised and reviewed by workgroups, including the proponent and key stakeholders. Through these workgroups and TAG review, modifications were suggested and made to help mitigate impact on small business, and to clarify and simplify the language. Impact on existing buildings was mitigated; allowing like-for-like replacement of existing water heaters. Further modifications allowing more significant use of fuel gas appliances were reviewed and rejected by the TAG. These minority report opinions were forwarded to the Mechanical, Ventilation and Energy Codes Committee and the Council, along with the TAG recommendations, for review and consideration as alternate options for adoption.<sup>5</sup> The proposed rule also reflects two options. The Energy Code Technical Advisory Group recommended adoption of this proposed change, but if it is ultimately not adopted there are other changes that should occur. Option 2 includes these changes as recommended by the TAG. Option 1 under Section C404.2.1 provides changes to require efficiency upgrades and other small changes to coordinate with other proposals. There are also options within Section C406 contingent upon the adoption of this measure.

**Probable Benefits vs probable costs:** The average net present value capital cost increase for this proposal will be around \$2.47/square foot. The proposal will have a life cycle cost increase of \$2.43/square foot when not accounting for the social cost of carbon. When accounting for the adjusted social cost of carbon, the heat pump water heater proposal will have a \$0.38/sq ft savings.

---

<sup>5</sup> [https://sbcc.wa.gov/sites/default/files/2021-08/136\\_Minority\\_Amendments\\_081221.pdf](https://sbcc.wa.gov/sites/default/files/2021-08/136_Minority_Amendments_081221.pdf)

See page 21 of the referenced economic and lifecycle cost analysis for further information.<sup>6</sup> The average energy savings will be approximately 5.5 kBtu per square foot. There is no anticipated increase in plan review or inspection time.

Benefits to building owners include early alignment with the Clean Buildings Bill (to avoid future performance compliance penalties) and annual energy costs for water heating. Given the state's climate goals and policy, this Energy Code proposal will help ensure new assets permitted beginning July 1, 2023, will not need to be immediately retrofitted to conform with the Clean Buildings requirements.

---

### **Electrical receptacles at gas appliances, Proposal 21-GP1-179**, Adds a new section to WAC 51-11C-40507

**Brief Description:** Requires an electrical receptacle or junction box placed at the location of installed gas range, cooktop or over; gas clothes dryer, or gas water heater to enable future "plug and play" installation of electric appliances.

**Purpose of Change:** The installation of electrical infrastructure at the time of construction is cheaper and easier to install versus retrofitting. With the state focus on greenhouse gas reduction and reduction of fossil fuel appliances, it is assumed that future replacement will be with electric versions of household appliances.

**Review Process:** The Technical Advisory Group reviewed this proposal and made a few technical corrections to the requirements. They felt this was a reasonable requirement in light of state policy, although this was not a unanimous opinion.

**Probable benefits vs. probable costs:** There is an estimated cost of \$250 per receptacle with no associated energy savings. Assuming an apartment has only one gas appliance installed, typically a stove, the average cost would be \$0.33 per square foot. This would eliminate any additional cost when and if the appliance(s) is replaced in the future.

---

### **Renewable Energy Required, Proposal 21-GP1-078**, Adds a new section to WAC 51-11C-41100.

**Brief Description:** Adds requirement for deployment of on-site renewable energy for commercial buildings over 10,000 sf.

**Purpose of Change:** To achieve state mandates of 70% energy use reduction by 2030, it will be necessary to incorporate some renewable energy into buildings to offset energy use. Renewable deployment needs to begin immediately to build up industry capacity to meet anticipated needs in the building sector over the next decade. This proposal starts down this path with modest renewable energy deployment requirements for commercial buildings. Renewable deployment also supports clean building and clean grid policies set by the state.

---

<sup>6</sup> [https://sbcc.wa.gov/sites/default/files/2021-12/136\\_Economic\\_Package.pdf](https://sbcc.wa.gov/sites/default/files/2021-12/136_Economic_Package.pdf)

**Review Process:** The Technical Advisory Group discussed this proposal over two meetings, with a meeting of a workgroup in between the two meetings. The workgroup centered around the costs, which showed a wide range, both higher and lower than those used in the cost calculations below. The general trend was that smaller systems cost more per Watt than larger systems, and the installation costs continue to decrease. The TAG also heard testimony from the Washington Public Utility Districts Association questioning the assumptions on payback in the cost analysis.

**Probable benefits vs. probable costs:** The proponent states this proposal results in 3-17% electricity savings for tenants and businesses and annual operating energy costs savings between \$1,140.98 to \$25,253.58 while resulting in an increase in first cost to building owners. On-site renewable generation provides a layer of resiliency against utility blackouts and other climate-related power supply events. This resiliency benefit has not been included in the economic impact analysis below.

Using the sources cited in the references, an intermediate cost (not the lowest) of \$1.72/Wdc installed cost for nonresidential PV systems was used. This installed cost is reported by NREL. The SEIA report on the U.S. market states a lower cost of \$1.36/Wdc, whereas other sources report slightly higher cost. With the PV and battery measure for nonresidential new construction in California's energy code (to be adopted in June 2021), and global and U.S. trends for installed PV costs, it is likely PV costs will continue to reduce and will be lower than today's costs by the time this measure is enforced for buildings in Washington state.

#### **Energy and Cost Savings**

1. Prototypical buildings developed by PNNL were used to develop energy and energy cost savings. PV system size (kW) was calculated based on the floor area and the 0.50 W/sf requirement.
2. NREL's PVWatts tool was used to estimate the PV generation in Seattle, WA. It is likely that generation will be higher in eastern Washington, given the higher solar resource.
3. EIA's energy prices for Washington State in 2021 were used (\$0.092/kWh).
4. A simple payback of 17 years was calculated based on the installed cost and annual energy cost savings.

<b>Prototype</b>	<b>Floor Area</b>	<b># of Stories</b>	<b>kW Required</b>	<b>kWh Generation</b>	<b>Installed System Cost</b>	<b>Annual Energy Cost Savings</b>	<b>Simple Payback</b>
Large Office	498,000	13	249	273,900	\$428,280	\$25,253.58	16.95
Medium Office	53,600	3	27	29,480	\$46,096	\$2,718.06	16.95
Small Office	5,500	1	3	3,025	\$4,730	\$278.91	16.95
Standalone Retail	24,700	1	12	13,585	\$21,242	\$1,252.54	16.95
Stripmall Retail	22,500	1	11	12,375	\$19,350	\$1,140.98	16.95
Primary School	73,960	1	37	40,678	\$63,606	\$3,750.51	16.95
Secondary School	210,900	2	105	115,995	\$181,374	\$10,694.74	16.95
Warehouse	49,495	1	25	27,222	\$42,566	\$2,509.89	16.95
Mid-rise Apartment	33,700	4	17	18,535	\$28,982	\$1,708.93	16.95
High-rise Apartment	84,360	10	42	46,398	\$72,550	\$4,277.90	16.95

**Review Process:** Testimony was received from the Washington Public Utility Districts Association stating that “the assumed retail price of electricity of \$0.092/kWh is too high. It appears that the proponent looked to the Energy Information Agency (report EIA-861, 2019 data) and divided total revenue from commercial customers in Washington by total was delivered to those customers to come up with the estimated retail price. However, the total revenue includes fixed and demand charges. If the TAG is to use averages, the better estimate is from retail utility commercial energy rates. Those averaged \$0.0619/kWh in 2018. However, averages mask the wide variability in commercial energy rates among Washington utilities. For example, the current commercial retail electric rates for Chelan and Douglas PUDs are \$0.016 and \$0.021/kWh, respectively, while Jefferson and Klickitat PUDs are \$0.0785 and \$0.084/kWh. If this proposal is adopted, customer savings are going to vary dramatically depending on the electric utility serving that customer. Also, if either “net metering” threshold identified in 1.a. is exceeded, then the utility is free to treat the facility as no different than any other power producer and pay wholesale market prices for electricity from that facility.” Based on information from WPUA, payback ranges from 25 to 97 years rather than the stated 17 years.

Conflicting testimony was received from the Washington Solar Energy Industries Association stating that “WAPUDA’s economic analysis exaggerates the impact net metering statute would play on grid-tied solar installations under the proposal’s changes to the code. Based on U.S. Department of Energy figures, the present day average electrical consumption of a commercial building is 22.5 kWh/sq ft... These solar installations would simply replace a portion of the building’s expected electrical load and the electricity would be consumed onsite. Very little would be returned to the grid and therefore the retail rate is the correct valuation for the energy as documented in the Proposal. Additionally, the \$0.09/kWh energy price disputed by WAPUDA is more likely too conservative than too high. The 2021 Washington State Energy Strategy projects the state’s overall electrical load will double by 2045 because of aggressive efforts to electrify transportation, buildings and the industrial sector. While this further proves my above point that the electricity produced by the amendment’s provisions will continue to be consumed onsite, it also undoubtedly puts an upward pressure on electricity rates statewide, across all building prototypes.”

While the TAG did recognize there was a minority report regarding the cost of the system, it was felt that on-site generation is a necessary piece of the code requirements to be able to reach the 70 percent reduction/net-zero energy goals of the guiding statute.

---

**CMU Walls, Proposal 21-GP1-207**, Modifies footnote c on Table C402.1.3 and footnote d on Table C402.1.4.

**Proposal 21-GP1-208**, Eliminates footnote c on Table C402.1.3 and footnote d on Table C402.1.4

**Brief Description:** There are two options offered for both opaque thermal envelope tables. Option 1 (207) modifies the mass wall footnote c, limiting the application of the exception single wythe concrete block walls exposed on both sides. Option 2 (208) removes the exception.

**Purpose of Change:** This code proposal would increase the efficiency of CMU wall without additional construction costs. This proposal is consistent with the code development objectives of RCW 19.27A.020(2)(a) and RCW 19.27A.160. It is important to modernize the application of Concrete Masonry Unit (CMU) walls for the code to achieve the anticipated energy savings. This code proposal would eliminate the allowance for vermiculite core fill of covered/finished CMU walls which will effectively double the thermal resistance of effected walls by lowering the wall U-factor from 0.24 for vermiculite filled cores per this exception to 0.104 for insulating per C402.1.3/C402.1.4. This proposal is supported by the economic analysis done by Mike Kennedy for the 2015 code cycle, based on a study for the Bonneville Power Administration<sup>7</sup>.

**Probable benefits vs. probable costs:** The table below lists the cost of labor and materials of insulating per C402.1.3/C402.1.4 of per the exceptions of footnotes c of C402.1.3 or d of C402.1.4. This table illustrates that for buildings finishing exterior CMU walls the costs to meet the prescriptive requirements of C402.1.3/C402.1.4 is no greater than that of compliance through the exceptions to C402.1.3 or C402.1.4.

Based on RS Means 2014 with cost data adjusted for inflation rate for the period between January 2014 and April 2021 per [on-line inflation calculator](#) maintained by the [U.S. Bureau of Labor Statistics](#) (BLS).

Insulation Strategy	U-Factor	Materials & Labor \$/sf
Vermiculite, 50% of Cores (RSM p. 229) per exception	0.24	\$1.30/sf
R-9.5 CI Interior (RSM p. 242) per C402.1.3/C402.1.4.	0.104	\$1.29/sf

Key Analysis Variables (207 & 208)		Building Characteristics	
Study Period (years)	50	Gross (Sq.Ft)	24,695
Nominal Discount Rate	74.11%	Useable (Sq.Ft)	0
Maintenance Escalation	1.00%	Space Efficiency	0.0%
Zero Year (Current Year)	2020	Project Phase	0
Construction Years	0	Building Type	0

Life Cycle Cost Analysis (207)		BEST	
Alternative	Baseline	Alt. 1	Alt. 2
Energy Use Intensity (kBtu/sq.ft)	35.5	34.3	34.2
1st Construction Costs	\$14,557	\$14,445	\$18,365
PV of Capital Costs	\$14,557	\$14,445	\$18,365
PV of Maintenance Costs			
PV of Utility Costs	\$28,086	\$27,072	\$26,967
<b>Total Life Cycle Cost (LCC)</b>	<b>\$42,643</b>	<b>\$41,518</b>	<b>\$45,332</b>
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$1,126</b>	<b>\$ (2,688)</b>

<sup>7</sup> [https://sbcc.wa.gov/sites/default/files/2021-07/207\\_CMU\\_Evaluation\\_19July2015\\_MK.pdf](https://sbcc.wa.gov/sites/default/files/2021-07/207_CMU_Evaluation_19July2015_MK.pdf)



<b>(GHG) Social Life Cycle Cost (207)</b>		<b>BEST</b>	
	Baseline	Alt. 1	Alt. 2
GHG Impact from Utility Consumption			
Tons of CO2e over Study Period	1,202	1,166	1,163
% CO2e Reduction vs. Baseline	N/A	3%	3%
Present Social Cost of Carbon (SCC)	\$10,201	\$9,838	\$9,800
<b>Total LCC with SCC</b>	<b>\$52,844</b>	<b>\$51,356</b>	<b>\$55,132</b>
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$1,488</b>	<b>\$ (2,288)</b>

<b>Life Cycle Cost Analysis (208)</b>		<b>BEST</b>	
Alternative	Baseline	Alt. 1	Alt. 2
Energy Use Intensity (kBtu/sq.ft)	35.5	34.3	34.3
1st Construction Costs	\$14,557	\$42,776	\$48,039
PV of Capital Costs	\$14,557	\$42,776	\$48,039
PV of Maintenance Costs			
PV of Utility Costs	\$28,086	\$27,072	\$27,072
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 42,643</b>	<b>\$69,849</b>	<b>\$75,112</b>
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$(27,205)</b>	<b>\$(32,468)</b>
<b>(GHG) Social Life Cycle Cost (208)</b>			
		<b>BEST</b>	
	Baseline	Alt. 1	Alt. 2
GHG Impact from Utility Consumption			
Tons of CO2e over Study Period	1,202	1,166	1,166
% CO2e Reduction vs. Baseline	N/A	3%	3%
Present Social Cost of Carbon (SCC)	\$10,201	\$9,838	\$9,838
<b>Total LCC with SCC</b>	<b>\$52,844</b>	<b>\$79,687</b>	<b>\$84,950</b>
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ (26,843)</b>	<b>\$ (32,106)</b>

While the TAG recommended that both proposals move forward for public comment, with Council concurrence, based on the life cycle cost analysis it would appear that Proposal 208, while reducing carbon emissions by 3%, does not show either net present savings or social life cycle cost savings over current code requirements. Proposal 207 does show modest savings.

---

**HVAC Total System Performance Ratio, Proposal 21-GP1-69:** Modifies WAC 51-11C-40310, Section C403.1.1 and WAC 51-11C-80500, Appendix D

**Purpose of code change:** This change expands the scope of TSPR to cover multifamily residential buildings and also provides revisions to Appendix D: Calculation of HVAC Total System Performance Ratio to provide additional clarifications based on interpretation requests received, incorporate

revisions made to Seattle energy code, and add additional system parameters added to Table D601.11.2. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Review Process:** The TAG spent some time in reviewing this proposal, and the modifications made were for clarity rather than any of the technical aspects. The final version was recommended with no stated opposition.

**Probable benefits vs. probable costs:** The estimated incremental cost for the expansion into multifamily is \$0.02 per square foot or about \$20 per dwelling unit) based on the design cost for a 60 unit apartment. It will likely not add to construction costs. For the multifamily buildings added to the scope of TSPR it is anticipated that a code official might need to spend 0.5 to 1.5 hours reviewing the submitted material.

The estimated annual energy savings for multifamily residential buildings is 1.94 kBtu per square foot.

The goal of the Total System Performance Ratio is to compare an HVAC system to systems with good known performance and efficiency to set a performance baseline for installed systems. A more efficient HVAC system will reduce life cycle costs for owners and tenants and lower carbon emissions. As Washington State works to achieve a 70 percent reduction in new building energy use, performance based codes will likely become more necessary and prevalent. The HVAC system performance requirements familiarize users with this approach and help establish a performance path towards Washington's long term goals.

---

**Indoor Horticulture Dehumidification, Proposal 21-GP1-95:** Adds a new section as WAC 51-11C-40394.

**Purpose of code change:** This proposal adds requirements for dehumidification efficiency for indoor growing facilities.

With lighting for indoor plant growth and maintenance becoming regulated under the 2021-IECC, HVAC loads emerge as the next major opportunity to improve the energy efficiency of indoor horticulture. Of those, dehumidification is the load that is the most under/un-addressed in the existing WSEC. This proposal is based on the requirements currently being adopted for the 2022 edition of Title 24.

This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Review Process:** The proposed language gives multiple options for meeting the requirement, which allows indoor growing facilities to options to integrate compliance dehumidification systems into multiple different HVAC designs and does not force facilities into a single dehumidification strategy.

There is currently no national standard for indoor growing dehumidification equipment. 10 CFR, Part 430, Subpart B - Appendix X1 does provide a method for measuring the energy input for standalone dehumidifiers, so this has been leveraged to set the threshold for that type of equipment. However, standalone equipment will not be an appropriate strategy for all facilities, so the proposal also includes options to utilize recovered energy for dehumidification reheat needs.

**Probable benefits vs. probable costs:** The CASE Report<sup>8</sup> found incremental costs of \$8.11 per square foot of growing area. Total cost per square foot of building would vary based on how much of the facility is dedicated to non-growing uses. The savings per total building square footage would vary depending on the amount of space dedicated to non-growing uses. The CASE Report found that savings for CA climate zones 1,2 & 16 (the closest match to WA's climate zones), was 80-81 kBtu per square foot per year.<sup>9</sup> There will also be additional time required for both plan review and site inspection. The additional time should be minimal as this requirement just adds one additional criterion to equipment that plan checkers and site inspectors are already checking.

---

**Demand Responsive Water Heating, Proposal 21-GP1-99:** Adds new section, WAC 51-11C-40414.

**Brief Description:** This proposal adds demand responsive control requirements for certain water heaters.

**Purpose of change:** The revision provides editorial changes that align the language with the terminology to denote these water heaters in the water heating equipment efficiency table. The protocol has been changed to CTA-2045-A. Conversations with AHRI have indicated that there may not sufficient availability of equipment that meets CTA-2045-B by the time this code goes into effect. It also clarifies that the alternate demand responsive control needs to be equivalent to CTA-2045-A.

Water heaters can provide significant load shifting and energy storage capacity in many building types. ANSI/CTA-2045 standardizes the socket, and communications protocol, for heat pump water heaters so they can communicate with the electricity grid other demand response signal providers. In addition, 2045 adds control and communications requirements for mixing valves in heat pump water heaters to enable them to provide greater storage capacity to support increased load shifting. This proposal requires that water heaters with integrated storage tanks have this demand control functionality. The water heaters subject to this requirement generally serve lavatories and kitchenettes in commercial buildings and some water heating approaches in mid-rise residential.

**Review Process:** There was considerable discussion and modification of this proposal at the TAG level. There was concern expressed early on from manufacturers that this requirement conflicted with the rules developed by Commerce and a workgroup was formed to address industry concerns. The proposal going forward was modified to limit applicability and not conflict with the Commerce Department rule (WAC 194-24-180).

---

<sup>8</sup> Final CASE Report: Controlled Environment Horticulture, California Statewide Codes and Standards Enhancement (CASE) Program, Oct. 2020, <https://title24stakeholders.com/wp-content/uploads/2020/10/2022-T24-NR-CEH-Final-CASE-Report.pdf>.

<sup>9</sup> Final CASE Report: Controlled Environment Horticulture, California Statewide Codes and Standards Enhancement (CASE) Program, Oct. 2020, <https://title24stakeholders.com/wp-content/uploads/2020/10/2022-T24-NR-CEH-Final-CASE-Report.pdf>.

**Probable benefits vs. probable costs:** Grid flexibility is one of the foundations of achieving meaningful decarbonization of building energy as it is an essential element of decarbonizing the electrical grid. Carbon free energy sources like solar and wind have varying production over the course of the day and the year. Demand responsive controls that can respond to demand response signals enable buildings to shape their loads to better align with available energy production. This could come in the form of curtailing energy use when demand is high or utilizing excess production for building tasks like pre-conditioning spaces or service hot water when demand is lower.

Demand control functionality will present a cost-saving opportunity for buildings in the future. More and more utilities are moving beyond voluntary programs and are expanding use of time-of-use rates for electricity as a tool for shaping demand. Installing demand-responsive lighting controls now will allow building tenants and owners to better control their utility costs. Since this requirement is part of the construction code, it will not require buildings to participate in any demand response programs. But it will ensure that buildings are capable of participating, so that buildings will be able to help integrate building loads with available production.

There are two cost scenarios for CTA-2045-enabled water heaters:

- **Heat Pump Water Heaters:** CTA-2045 has become a largely standard (but not universal) feature of heat pump water heaters. Rheem and AO Smith, the brands carried by Home Depot and Lowes, both include CTA-2045 ports. Therefore, for buildings that are already utilizing unitized HPWHs to meet performance requirements, the incremental cost is \$0 through product selection.
- **Electric Resistance Water Heaters:** CTA-2045 electric resistance water heaters have been produced, but don't seem to be widely available since HPWHs have taken over the energy efficient segment of the market. Therefore, the most straightforward way to implement CTA-2045 is to move to a HPWH with an incremental cost in the \$1000 range. However, many utilities in WA offer incentives in the \$500 range.
  - Rheem 40-gal "Performance" electric resistance: \$379<sup>10</sup>
  - Rheem 50-gal "Performance Platinum" HPWH: \$1399<sup>11</sup>

This proposal will add a minimal amount of extra plan review. Spec sheets will need to be checked to ensure that the water heater meets the requirement. There should be no additional inspection time if site inspectors are checking that water heating equipment is consistent with the construction documents.

---

<sup>10</sup> <https://www.homedepot.com/p/Rheem-Performance-40-Gal-Medium-6-Year-4500-4500-Watt-Elements-Electric-Tank-Water-Heater-XE40M06ST45U1/205810725>. Accessed 6/30/2021

<sup>11</sup> <https://www.homedepot.com/p/Rheem-Performance-Platinum-50-Gal-10-Year-Hybrid-High-Efficiency-Smart-Tank-Electric-Water-Heater-XE50T10H45U0/312742081>. Accessed 6/30/2021

**Compressed Air Systems, Proposal 21-GP1-193:**

**Purpose of code change:** Adds new code section regulating compressed air systems. Language is taken from proposed Title 24 2022 language and is similar but much more comprehensive to City of Seattle requirements. The intent is that this would apply to process loads. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031 and reduce greenhouse gas emissions.

**Review process:** The TAG discussed adding further exceptions for laboratories and oil-free compressors, but in the end they decided to recommend that it go to public hearing as presented.

**Probable benefits vs. probable costs:** Increased first costs and decreased utility bills. The costs and saving are determined from Title 24 CASE Reports<sup>12</sup>. In both reports portions of the requirements were evaluated in 4 prototypes. For each requirement, data from the prototype where it was least cost effective was used to evaluate the measure in the OFM calculator. Thus the estimate cost benefit is very conservative

No independent cost estimate was made. Costs and saving are determined from Title 24 Case reports.

This proposal will require jurisdictions to review compressed air designs and verify testing and monitoring. A complete guess but maybe 4 hours per permit that has systems of this scale which is a small fraction of the total permits.

Requirement	T24 Worst Case	Initial Cost	Annual Energy Savings	Ongoing expense
Auto-shut down timer	Prototype 3	\$6173	7025kWh	
Trim Compressor	Operating Profile 3 / 25 hp	\$4000	8293kWh	
Pipe Sizing	Prototype 4	\$272982	210147 kWh	
Monitoring	Prototype 1	\$10685	42058 kWh	\$300/yr data services for 2 comps + \$500 every 5 for calibration
Leak Testing	Prototype 3	\$3342	6548 kWh	

<sup>12</sup> Pipe Sizing, Monitoring, and Leak Testing for Compressed Air Systems: [https://title24stakeholders.com/wp-content/uploads/2020/06/NR-Compressed-Air\\_Draft-CASE-Report.pdf](https://title24stakeholders.com/wp-content/uploads/2020/06/NR-Compressed-Air_Draft-CASE-Report.pdf); Final Case Report. Sept 2020. Prepared by AESC, Inc. and Energy Solutions: <https://title24stakeholders.com/wp-content/uploads/2020/01/T24-2013-Final-CASE-Report-AirCompressors.pdf>

Smart Controls

<b>Life Cycle Cost Analysis</b>		<b>BEST</b>		
Alternative	Baseline	Alt. 1	Alt. 2	
Energy Use Intensity (kBtu/sq.ft)	#DIV/0!	#DIV/0!	#DIV/0!	
1st Construction Costs	\$ -	\$ 6,173	\$ -	
PV of Capital Costs	\$ -	\$ 15,237	\$ -	
PV of Maintenance Costs	\$ -	\$ -	\$ -	
PV of Utility Costs	\$ 333,677	\$ 310,236	\$ 333,677	
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 333,677</b>	<b>\$ 325,474</b>	<b>\$ 333,677</b>	
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$ 8,204</b>	<b>\$ -</b>	

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

<b>(GHG) Social Life Cycle Cost</b>		<b>BEST</b>		
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2	
Tons of CO2e over Study Period	2,059	1,915	2,059	
% CO2e Reduction vs. Baseline	N/A	7%	0%	
Present Social Cost of Carbon (SCC)	\$ 130,707	\$ 121,525	\$ 130,707	
<b>Total LCC with SCC</b>	<b>\$ 464,385</b>	<b>\$ 446,999</b>	<b>\$ 464,385</b>	
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 17,386</b>	<b>\$ -</b>	

Trim Compressor

<b>Life Cycle Cost Analysis</b>		<b>BEST</b>		
Alternative	Baseline	Alt. 1	Alt. 2	
Energy Use Intensity (kBtu/sq.ft)	#DIV/0!	#DIV/0!	#DIV/0!	
1st Construction Costs	\$ -	\$ 4,000	\$ -	
PV of Capital Costs	\$ -	\$ 9,873	\$ -	
PV of Maintenance Costs	\$ -	\$ -	\$ -	
PV of Utility Costs	\$ 333,677	\$ 306,005	\$ 333,677	
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 333,677</b>	<b>\$ 315,879</b>	<b>\$ 333,677</b>	
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$ 17,798</b>	<b>\$ -</b>	

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

<b>(GHG) Social Life Cycle Cost</b>		<b>BEST</b>		
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2	
Tons of CO2e over Study Period	2,059	1,888	2,059	
% CO2e Reduction vs. Baseline	N/A	8%	0%	
Present Social Cost of Carbon (SCC)	\$ 130,707	\$ 119,868	\$ 130,707	
<b>Total LCC with SCC</b>	<b>\$ 464,385</b>	<b>\$ 435,747</b>	<b>\$ 464,385</b>	
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 28,638</b>	<b>\$ -</b>	

Pipe Sizing

<b>Life Cycle Cost Analysis</b>		<b>BEST</b>		
Alternative	Baseline	Alt. 1	Alt. 2	
Energy Use Intensity (kBtu/sq.ft)	#DIV/0!	#DIV/0!	#DIV/0!	
1st Construction Costs	\$ -	\$ 272,982	\$ -	
PV of Capital Costs	\$ -	\$ 673,819	\$ -	
PV of Maintenance Costs	\$ -	\$ -	\$ -	
PV of Utility Costs	\$ 3,336,772	\$ 2,635,559	\$ 3,336,772	
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 3,336,772</b>	<b>\$ 3,309,378</b>	<b>\$ 3,336,772</b>	
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$ 27,394</b>	<b>\$ -</b>	

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

<b>(GHG) Social Life Cycle Cost</b>		<b>BEST</b>		
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2	
Tons of CO2e over Study Period	20,592	16,265	20,592	
% CO2e Reduction vs. Baseline	N/A	21%	0%	
Present Social Cost of Carbon (SCC)	\$ 1,307,074	\$ 1,032,396	\$ 1,307,074	
<b>Total LCC with SCC</b>	<b>\$ 4,643,845</b>	<b>\$ 4,341,774</b>	<b>\$ 4,643,845</b>	
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 302,071</b>	<b>\$ -</b>	

## Monitoring

Life Cycle Cost Analysis		BEST		
Alternative	Baseline	Alt. 1	Alt. 2	
Energy Use Intensity (kBtu/sq.ft)	#DIV/0!	#DIV/0!	#DIV/0!	
1st Construction Costs	\$ -	\$ 10,685	\$ -	
PV of Capital Costs	\$ -	\$ 26,374	\$ -	
PV of Maintenance Costs	\$ -	\$ 13,601	\$ -	
PV of Utility Costs	\$ 3,336,772	\$ 3,196,434	\$ 3,336,772	
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 3,336,772</b>	<b>\$ 3,236,409</b>	<b>\$ 3,336,772</b>	
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$ 100,362</b>	<b>\$ -</b>	

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

(GHG) Social Life Cycle Cost		BEST		
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2	
Tons of CO2e over Study Period	20,592	19,726	20,592	
% CO2e Reduction vs. Baseline	N/A	4%	0%	
Present Social Cost of Carbon (SCC)	\$ 1,307,074	\$ 1,252,101	\$ 1,307,074	
<b>Total LCC with SCC</b>	<b>\$ 4,643,845</b>	<b>\$ 4,488,510</b>	<b>\$ 4,643,845</b>	
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 155,335</b>	<b>\$ -</b>	

## Leak Detection

Life Cycle Cost Analysis		BEST		
Alternative	Baseline	Alt. 1	Alt. 2	
Energy Use Intensity (kBtu/sq.ft)	#DIV/0!	#DIV/0!	#DIV/0!	
1st Construction Costs	\$ -	\$ 3,342	\$ -	
PV of Capital Costs	\$ -	\$ 8,249	\$ -	
PV of Maintenance Costs	\$ -	\$ -	\$ -	
PV of Utility Costs	\$ 3,336,772	\$ 3,314,923	\$ 3,336,772	
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 3,336,772</b>	<b>\$ 3,323,172</b>	<b>\$ 3,336,772</b>	
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$ 13,600</b>	<b>\$ -</b>	

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

(GHG) Social Life Cycle Cost		BEST		
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2	
Tons of CO2e over Study Period	20,592	20,457	20,592	
% CO2e Reduction vs. Baseline	N/A	1%	0%	
Present Social Cost of Carbon (SCC)	\$ 1,307,074	\$ 1,298,515	\$ 1,307,074	
<b>Total LCC with SCC</b>	<b>\$ 4,643,845</b>	<b>\$ 4,621,687</b>	<b>\$ 4,643,845</b>	
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 22,159</b>	<b>\$ -</b>	

### Reduced Threshold for LPA Compliance on Remodels, Proposal 21-GP1-180: Amends Section C503.7.2 within WAC 51-11C-50300

**Brief Description:** Requires alterations replacing 20 percent or more of existing lighting fixtures to comply with the lighting power allowance in Section C405. The previous threshold was 50 percent. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Purpose of change:** This proposal is based on current requirements in the Seattle code. The proposals lowered the threshold for replacement lighting needing to meet the lighting power allowance, requiring more projects to upgrade to more efficient lighting. Lighting is one of the largest end uses of electricity within commercial buildings.

**Review Process:** There was some concern that this may have a negative impact on retrofit projects, but it was noted that this reduction was championed at ASHRAE by Puget Sound Energy. The TAG was generally in agreement with the proposal.

**Probable benefits vs. probable costs:** A detailed analysis was not done, since there were no control requirements, just a lower lighting power allowance

Cost: Estimate of \$0.75 per square foot. Energy Savings: Estimate of 0.13 kWh per square foot.

**Boiler Controls, Proposal 21-GP1-139:** Modifies WAC 51-11C-40334.

**Brief Description:** Adds definitions for commercial and process boilers and adds a new section with criteria for combustion air controls and minimum stack gas oxygen concentration levels for boiler systems. These requirements are applied to commercial building and process boilers.

**Purpose of Change:** Boiler oxygen controls, combustion air controls, and variable fan motors have been commonplace in other state codes on larger boilers for quite some time. This proposal would align requirements forthcoming in California Title 24 with the forthcoming code in WA as the specifications are the same. The effect will be an improvement in the part-load operation of larger boilers. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Review Process:** There was little discussion or controversy at the TAG level for this proposal. The requirements have been in effect in California for a few years.

**Probable benefits vs. probable costs:** The analysis is based on EnergyPlus modeling of prototype buildings for California CASE study for 2022 Title 24.<sup>13</sup> Savings shown here are assuming a large office building in CA Climate Zone 2 (equivalent to CZ 4C) which is 13 stories. Provisions shown to be cost-effective for commercial boilers in all modeled scenarios for this climate zone except mixed use and apartment high-rise. Process boilers cost-effective in all cases due to constant load assumptions.

Estimated incremental cost: \$0.098/square foot:

Flue damper cost = \$1665 (\$1500 2013 inflated 11% to 2021) + \$166 (\$150 2013 inflated 11%) every 10 years

VFD cost = \$4716 (\$4249 2013 inflated 11% to 2021) + ½ hour per year in maintenance @\$100/hr

O2 trim controls cost = \$7500 (2022) + 4 hours per year in maintenance @\$100/hr

Estimated annual energy savings: 2.116 KBTU/ square foot:

Flue damper – 2.5 mmbtu boiler 229 therms

VFD – 10 hp fan 4080 kWh

O2 trim controls – 5 mmBtu boiler 2746 therms

<sup>13</sup> Final CASE report available here: [https://title24stakeholders.com/wp-content/uploads/2020/08/NR-Boilers-and-Water-Heating\\_Final-CASE-Report.pdf](https://title24stakeholders.com/wp-content/uploads/2020/08/NR-Boilers-and-Water-Heating_Final-CASE-Report.pdf)

Key Analysis Variables		Building Characteristics	
Study Period (years)	50	Gross (Sq.Ft)	147,176
Nominal Discount Rate	5.00%	Useable (Sq.Ft)	147,176
Maintenance Escalation	1.00%	Space Efficiency	100.0%
Zero Year (Current Year)	2020	Project Phase	0
Construction Years	0	Building Type	0

Life Cycle Cost Analysis		BEST	
Alternative	Baseline	Alt. 1	Alt. 2
Energy Use Intensity (kBtu/sq.ft)	246.2	244.0	
1st Construction Costs	\$	\$13,881	\$
PV of Capital Costs	\$	\$34,439	\$
PV of Maintenance Costs	\$	\$18,702	\$
PV of Utility Costs	\$19,826,323	\$19,714,377	\$
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 19,826,323</b>	<b>\$ 19,767,518</b>	<b>\$</b>
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$58,806</b>	<b>\$</b>

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

(GHG) Social Life Cycle Cost		BEST	
	Baseline	Alt. 1	Alt. 2
GHG Impact from Utility Consumption			
Tons of CO2e over Study Period	71,232	70,427	-
% CO2e Reduction vs. Baseline	N/A	1%	101%
Present Social Cost of Carbon (SCC)	\$4,659,220	\$4,607,990	\$
<b>Total LCC with SCC</b>	<b>\$24,485,543</b>	<b>\$24,375,508</b>	<b>\$</b>
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$110,036</b>	<b>\$-</b>

**Fan Power Allowance, Proposal 21-GP1-138:** Replaces Section C403.8.1 and associated tables in WAC 51-11C-4038

**Brief Description:** Revises the fan power allowance tables and updates them to align with new fan power budget and allowances based on system type in the 2022 Title 24 code. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Purpose of Change:** This proposal updates the approach to fan power limitations and aligns with California's Title 24 method. Existing fan power limitations applies a "one-size-fits-all" approach to limiting fan power which leads to the requirements being easy to meet for many projects, especially with smaller fan systems. It has been widely acknowledged that the design of the current code requirements is somewhat stringent on larger systems, but less stringent for smaller fan systems. An assumption about the pressure drop a fan must overcome and fan efficiency is built into the existing

fan power limitations equation. Currently, the underlying total static pressure assumption in the fan power limitations is 5.35 in. wg for VAV fan systems and 3.85 in. wg for CAV systems, regardless of the fan system air flow or components. This has the effect of making it easy to meet the standard for smaller buildings with shorter duct runs with lower pressure drop, as compared to larger more complex buildings with longer duct runs (higher pressure drop).

This also moves the threshold down as there are many fan systems between 1 kW and 5 nameplate HP which were previously not subject to the fan power limitations. Fan power requirements have not changed since they were adopted by the WSEC 2012 and prior to that, 90.1-2001. Adopting title 24 fan power budgets could saving up to 12% of fan power per system, especially for multi-zone systems such as VAV and DOAS serving a larger number of spaces.

Finally, an allowance of 0.6 in. wg for supply systems and 0.3 in. wg for exhaust/return/relief systems (where the combined total equals 0.9 in. wg) is allowed for additions/alterations.

Re-designs fan power allowances section to become more stringent for smaller fan systems (which comprise a large market share and were previously exempt) and keeps stringency for larger fan systems.

**Review Process:** There was input from the engineers on the TAG who felt this was already being done from the design standpoint but had concerns about application to existing ductwork. The TAG modified the application to replacement of existing HVAC systems to mitigate the impact.

**Probable benefits vs probable costs:** Primarily benefits owners and tenants who pay electric bill to reduce energy consumption of fan systems serving the HVAC needs of the building.

Construction cost \$0.29/square foot

Annual energy savings 0.372 KWH/ square foot

Some increase in review time expected in the beginning to identify whether designer correctly accounted for fan system power among all fans, especially smaller fans that were previously exempt.

The incremental cost for the fan power budget was conservatively determined to be \$0.29/ft<sup>2</sup> and the B/C ratio averaged 3.8 across all building types modeled and all climate zones. A large office prototype model was used to determine likely layout and associated costs. Cost of ductwork designs were reviewed by a professional cost estimator and showed an incremental cost of \$0.27/ft<sup>2</sup> for a CAV and \$0.31/ft<sup>2</sup> for VAV system to comply with the new fan power budget allowances. This cost was largely due to larger diameter ductwork and better fittings selection, showing that compliance can be achieved through good design without equipment changes (though that is also another method to comply with the new fan power budget thresholds).

Detailed cost information was obtained from the Final CASE report for the 2022 Title 24.<sup>14</sup>

This proposal changes the current fan BHP or motor nameplate HP method to fan electrical input power to capture transmission and motor efficiency losses. The fan power budget electrical input power calculation is largely based on AMCA-208-18. (AMCA 2018). It also requires a fan power budget calculation be performed separately for each fan system and denotes the fan power as a function of airflow, system type, and components of the fan system, instead of just HP or bhp with adjustments. The proposed changes modeled in California prototype buildings showed a range between 12-34 percent per fan system, leading to a ~2 percent electricity savings per building.

---

<sup>14</sup> [https://title24stakeholders.com/wp-content/uploads/2020/09/2022\\_T24-Final-CASE-Report\\_Air-Distribution.pdf](https://title24stakeholders.com/wp-content/uploads/2020/09/2022_T24-Final-CASE-Report_Air-Distribution.pdf)

Expected building energy consumption based on CBSA average EUI's for large office building and CASE study prototype savings<sup>15</sup>.

Key Analysis Variables		Building Characteristics	
Study Period (years)	50	Gross (Sq.Ft)	32,100
Nominal Discount Rate	5.00%	Useable (Sq.Ft)	32,100
Maintenance Escalation	1.00%	Space Efficiency	100.0%
Zero Year (Current Year)	2020	Project Phase	0
Construction Years	0	Building Type	0

Life Cycle Cost Analysis		BEST	
Alternative	Baseline	Alt. 1	Alt. 2
Energy Use Intensity (kBtu/sq.ft)	24.6	23.3	
1st Construction Costs	\$	\$9,309	\$
PV of Capital Costs	\$	\$23,096	\$
PV of Maintenance Costs	\$	\$	\$
PV of Utility Costs	\$641,887	\$608,723	\$
<b>Total Life Cycle Cost (LCC)</b>	<b>\$641,887</b>	<b>\$631,818</b>	<b>\$</b>
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$10,069</b>	<b>\$</b>

(GHG) Social Life Cycle Cost		BEST	
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2
Tons of CO2e over Study Period	857	812	-
% CO2e Reduction vs. Baseline	N/A	5%	105%
Present Social Cost of Carbon (SCC)	\$61,205	\$58,042	\$-
<b>Total LCC with SCC</b>	<b>\$703,091</b>	<b>\$ 689,861</b>	<b>\$</b>
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 13,231</b>	<b>\$</b>

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

---

**PTAC U-factor, Proposal 21-GP1-160:** Adds a new section to WAC 51-11C-40214; Section C402.1.4.3

**Brief Description:** Requires heat loss through PTACs, PTHPs, and other through-wall mechanical equipment to be calculated as part of envelope U-factor compliance. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

---

<sup>15</sup> [https://title24stakeholders.com/wp-content/uploads/2020/09/2022\\_T24-Final-CASE-Report\\_Air-Distribution.pdf](https://title24stakeholders.com/wp-content/uploads/2020/09/2022_T24-Final-CASE-Report_Air-Distribution.pdf)

**Purpose of Change:** Provides a more realistic assessment of envelope heat loss through PTACs and PTHPs in exterior walls, which is several times greater than heat loss through a typical code-minimum exterior wall assembly.

**Review Process:** There was little discussion or controversy at the TAG level for this proposal. It was felt that this requirement would encourage the use of products requiring only a small envelope opening.

**Probable benefits vs. probable costs:** Costs and savings calculated per the assumptions listed below.

Estimated incremental cost: \$0.24 per square foot.

Estimated annual energy savings: \$95 per year savings

A typical PTHP unit fits in an opening of 42 x 16 inches = 4.7 square feet

Walls of an apartment building floor 65 x 100 x 11 feet floor-to-floor would be 3630 gross sf.

Subtracting 840 sf (12 apts x 69 sf each) for fenestration would leave 2790 sf

Assumed U-factor for PTAC = 0.5

Max U-factor for wood-framed walls = U-0.051

Opaque walls depreciated for PTHP = U-0.061

To bring those walls back to U-0.051 requires R-13 cavity + R-12 c.i. (instead of R-13 + R-7.5 c.i.)

From Table A103.3.1(2)

Additional cost for R-12 (2-1/2") insulation (instead of R-7.5 (1-12") c.i.)

Additional \$500 per 1000 sf @ 2734 sf = \$1,365 + \$200 for larger fasteners = \$1,565

Cost per sf of floor area = \$1565/6500 sf = \$0.24/sf

Seattle HDD = 4424 Spokane HDD = 6655

UA w/ PTHP = 0.061 x 2790 = 170 x 4424 HDD = 752,920 = 753 kBTU/3.4 = 221 KWH x \$0.11 x 24hr = \$583.44

UA w/o PTHP = 0.051 x 2790 = 142 x 4424 = 628,208 = 628 kBTU/3.4 = 185 KWH x \$0.11 x 24hr = \$488

\$583 - \$488 = \$95 per year savings

**Extend Heat Pump Requirement to Include Split Systems, Proposal 21-GP1-164:** Modifies Section C403.3.2.6 in WAC 51-11C-40332

**Brief Description:** Requires packaged and split systems providing heating and cooling, or cooling only, to be heat pumps. The requirement previously applied to packaged systems with both heating and cooling.

**Purpose of change:** Extend heat pump requirement from packaged equipment to include split systems. This may not be necessary if C403.1.4 heat pump requirement (21-GP1-103) is approved. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031 and reduce greenhouse gas emissions.

**Review Process:** This change was also impacted by another proposal, 21-GP1-194, which adjusted the configuration of heat pumps to allow more package terminal heat pump models to meet code.

While this code be seen as a lessening of the stringency of the code, the requirement for additional systems to meet the requirement compensates.

**Probable benefits vs. probable costs:** Estimate of the construction cost \$0.10 per square foot.

Estimate of the annual energy savings 5.4 KBTU per square foot

\$10,000 additional cost for 100,000 sf building

Typical EUI of 40, heating EUI of 8 (20% of total), 2/3 reduction by use of heat pump = 5.4 kbut/sf/yr

---

**High Capacity Space Heating Boiler, Proposal 21-GP1-133:** Adds a new section C403.3.4.5 to WAC 51-11C-40334.

**Brief Description:** Adds requirements from ASHRAE 90.1 for high capacity gas-fired hot water boiler systems to have condensing boilers.

**Purpose of Change:** Achieve energy savings in gas fired hot water heated buildings while staying close to national code language. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

ASHRAE published 90.1-2019 addendum bc implementing requirements for high capacity gas-fired hot water boiler systems to have condensing boilers. This language has been adapted to the WSEC with one modification being to delete renewable energy from the options of exception 1 due to the more mainstream role renewables are playing in code.

**Review Process:** This was another proposal that did not receive much discussion, as it was adopted into ASHRAE 90.1. The proposal has some interaction with boiler controls proposal, 21-GP1-139, but not outright conflicts.

**Probable benefits vs probable costs:** The cost analysis was taken from that done for ASHRAE 90.1-2019 addendum bc. There will possibly be a small amount of additional time necessary to review boiler system size and efficiency and design criteria used for coils. Since systems are generally central this effort will not be substantial

Average estimate of \$0.10 per kWh across various building types and climate zones. Energy Savings: Using the Standard 90.1 scalar ratio, the economic analysis shows an average scalar ratio of 4.2. The maximum scalar ratio of 17.2 for boilers with a life expectancy of 25 years. Models and estimates show that all prototypes fall within the maximum scalar ratio and are cost-effective.

First cost was determined from the 2012 GSA Condensing Boiler Study<sup>16</sup>, which estimates \$38.50/MBtu for noncondensing and \$42.00/MBtu for condensing boilers. In addition, the study estimates an additional average annual maintenance cost of \$400 for condensing boilers. Energy Savings were found using energy modeling simulations run using DOE's EnergyPlus. Three prototype buildings were used—large office, hospital and secondary school—in various US climate zones. A

---

<sup>16</sup> [https://www.gsa.gov/cdnstatic/GPG\\_Findings\\_004-Condensing\\_Boilers.pdf](https://www.gsa.gov/cdnstatic/GPG_Findings_004-Condensing_Boilers.pdf)

blended cost of \$0.10/kWh was assumed. Using the Standard 90.1 scalar ratio<sup>17</sup>, the economic analysis shows an average scalar ratio of 4.2. The maximum scalar ratio of 17.2 for boilers with a life expectancy of 25 years. Models and estimates show that all prototypes fall within the maximum scalar ratio and are cost-effective.

**Increasing ERV Effectiveness, Proposal 21-GP1-165:** Modifying Section C403.3.5.1 in WAC 51-11C-40335.

**Brief Description:** Increase ERV effectiveness to 60% enthalpy (from 50%) and limit main exception to spaces smaller than 650 sf.

**Purpose of Change:** Improve heat recovery effectiveness for non-residential occupancies, taking advantage of commonly available ERV equipment. Eliminate DCV exception for spaces larger than 650 sf.

This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Review Process:** The original proposal removed the sensible recovery effectiveness from the main body of the section and allowed it only for Group R-2. The TAG felt it should be retained because not all heat recovery ventilators have an enthalpy rating, so it may be advantageous to retain the sensible recovery rating. The sensible recovery effectiveness was increased from 60% to 68% to correlate with the original change.

**Probable benefits vs. probable costs:** Will slightly increase costs for ERVs in non-residential occupancies that require DOAS and will add energy recovery to larger spaces that have DCV. This will decrease heating and cooling costs.

Estimate of the construction cost is \$0.10 per square foot based on the assumption of a \$10,000 increase for HVAC cost for a 100,000 square foot building.

Estimated annual energy savings: Reduce annual HVAC energy usage by 2%, or about 0.3 kWh per square foot

$50 \text{ EU} \times 0.02/3.4 = 0.3 \text{ KWH/sf/yr @ } \$0.11 = \$0.03/\text{sf}$

If HVAC usage is 1/3 of total energy usage,  $0.03/3 = \$0.01/\text{sf}$

**Demand Responsive Thermostats, Proposal 21-GP1-97:** Adds new Section C403.4.1.7 to WAC 51-11C-40341

<sup>17</sup> [https://www.energycodes.gov/sites/default/files/2021-07/commercial\\_methodology.pdf](https://www.energycodes.gov/sites/default/files/2021-07/commercial_methodology.pdf)

**Brief Description:** Adds a requirement for demand responsive controls for thermostats in all buildings except health care and assisted living. It does not require participation in any demand response programs.:

**Purpose of Change:** Demand responsive functionality will present a cost-saving opportunity for buildings in the future. More and more utilities are moving beyond voluntary programs and are expanding use of time-of-use rates for electricity as a tool for shaping demand. Installing demand-responsive thermostats now will allow building tenants and owners to better control their utility costs.

Demand responsive functionality has been required in Title24 since the 2013 edition and was found cost effective in CA.<sup>18</sup> In the 8 years since, equipment prices have decreased (less than \$60 for a basic DR thermostat<sup>19</sup> compared to just under \$30 for a basic 7-day programmable thermostat<sup>20</sup>) and WA peak prices have increased.

**Review Process:** The TAG was initially concerned about how this change would impact some systems, and the proponent was asked to come back with a revision incorporating more of the language from the original Title 24 language. There was also some concern that what was provided may not be compatible with the utility programs. The final proposal does not include all of the Title 24 approach. The Title 24 approach is very prescriptive and can be restrictive, as evidenced by efforts in the 2022 proposals to open it up to accommodate emerging technologies. By being more descriptive in the requirements, this proposal will better accommodate this rapidly emerging field.

**Probable benefits vs. probable cost:** Estimated incremental construction cost: \$0.03 per square foot, based on an assumption of \$30 per unit controlling a 1000 square foot zone

$\$30/\text{unit} \times (10 \text{ units}) / 10,000\text{sf}$

10,000 sf office with 10 thermostat zones of 1000 sf each.

Estimated annual energy savings: A California study reported an annual energy savings of 83 to 274 kWh in CA climate zones 1, 2 and 16 (the closest analogous climate zones to WA's climate zones) for a 10,000 office<sup>21</sup>.

This proposal will add a minimal amount of extra plan review. Spec sheets will need to be checked to ensure that the thermostat meets the requirement. There should be no additional inspection time if site inspectors are checking that thermostats are consistent with the construction documents.

<sup>18</sup> *Final CASE Report: Upgradeable Setback Thermostats*, California Statewide Codes and Standards Enhancement (CASE) Program, October 2011, [https://title24stakeholders.com/wp-content/uploads/2020/01/2013\\_CASE-Report\\_Upgradeable-Setback-Thermostats.pdf](https://title24stakeholders.com/wp-content/uploads/2020/01/2013_CASE-Report_Upgradeable-Setback-Thermostats.pdf)

<sup>19</sup> <https://www.supplyhouse.com/Venstar-T3700-Explorer-T3700-Residential-Digital-Thermostat-2-Heat-1-Cool>

<sup>20</sup> <https://www.supplyhouse.com/Lux-P711-010-7-Day-5-2-day-Programming-or-Non-Programmable-Thermostat-Horizontal-Mount-1-Heat-1-Cool>

<sup>21</sup> *Final CASE Report: Upgradeable Setback Thermostats*, California Statewide Codes and Standards Enhancement (CASE) Program, October 2011, [https://title24stakeholders.com/wp-content/uploads/2020/01/2013\\_CASE-Report\\_Upgradeable-Setback-Thermostats.pdf](https://title24stakeholders.com/wp-content/uploads/2020/01/2013_CASE-Report_Upgradeable-Setback-Thermostats.pdf)

**Demand Control Ventilation, Proposal 21-GP1-190:** Revises Section C403.7.1, WAC 51-11C-40371

**Brief Description:** Replace current C403.7.1 with new section which removes energy recovery exception and reduces and reconfigures various thresholds. The proposal also adds specific requirements for DCV. Gas sensors are required in spaces and systems are required to have VSD control or as allowed modulated dampers. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Purpose of Change:** The intent is that DCV applies to all single zone systems (DOAS or other) that provide ventilation. Additionally, the intent is that a DOAS system larger than 1500 cfm that provides ventilation to more than one space also requires DCV (unless exceptions apply). The change will achieve energy savings by requiring DCV in many more cases and update language.

Spaces served by systems with heat recovery will no longer be exempt. Space size thresholds are changed from floor area to the people component cfm of outdoor air. Systems without economizer will have to start providing DCV down to 750 cfm or 1500 cfm with heat recovery rather than the current 3000 cfm.

The room size thresholds are derived from 90.1-2019 addendum b. First, the 90.1-2019 addendum b room size thresholds were reduced until the savings (scaled by area) and cost (fixed) were just cost effective in the OFM calculator including the price of carbon. This resulted in rooms sizes 57% smaller than 90.1-2019. In addition, the 90.1-2019 criteria of occupant outdoor air component in cfm per 1000 square feet was simplified to occupant outdoor air flow in cfm.

**Review Process:** The TAG reviewed this proposal and made several clarifying changes, but the proposal remain substantively as submitted. There were no dissenting opinions or objections to the recommended adoption.

**Probable benefits vs. probable cost:** Increased control and equipment costs and decreasing operating costs. Cost and savings are based upon 90.1-2019 addendum b (completed and published 4/1/2021<sup>22</sup>). Room and system size thresholds are scaled down to account for OFM calculator assumptions and carbon.

When cost-effective, demand control ventilation (DCV) should be required for occupied spaces, considering the required outdoor air for ventilation based on number of people in the space, varying space sizes, use of energy recovery equipment, and climate zone. The current requirement has a threshold based only on space size and space occupancy. This proposal seeks to more effectively align DCV requirements with all other relevant variables to produce a cost-effective solution.

The single-threshold parameters are replaced by a table where the floor area threshold requirement is based on climate zone and occupant outdoor airflow rates per 1000 ft<sup>2</sup> (100 m<sup>2</sup>) determined in accordance with ASHRAE Standard 62.1. The requirements are grouped by occupant outdoor airflow component ranges (cfm/1000 ft<sup>2</sup> [L/s/100 m<sup>2</sup>]) based on default parameters in Standard 62.1. While the exact value for a particular space type varies, the three groups in the table generally correspond to (a) retail, break rooms, or bank lobbies; (b) classrooms or conference rooms; and (c) lecture halls, theatre, or assembly.

---

22

[https://www.ashrae.org/file%20library/technical%20resources/standards%20and%20guidelines/standards%20addenda/90\\_1\\_2019\\_b\\_20210401.pdf](https://www.ashrae.org/file%20library/technical%20resources/standards%20and%20guidelines/standards%20addenda/90_1_2019_b_20210401.pdf)

The exhaust air energy recovery exception was removed and replaced with higher floor area thresholds in the table. The exception for design outdoor airflow less than 750 cfm was also removed, as this factor is accounted for in the cost-effectiveness analysis. One new exception was added to account for spaces that are not allowed to reduce outdoor airflow per the requirements in ASHRAE Standard 170, other applicable codes, or accreditation standards. The net effect of these changes will increase the cost of construction. Because an economizer or motorized dampers are already required by this section, the cost to add a sensor and wiring is expected to be \$300 or less per unit. A present value allowance of \$63 is added to the cost to allow for replacement of up to 50% of sensor elements halfway through the measure life. The square footage thresholds in the table result in cost effectiveness for a 15-year life control measure based on a calculated discounted payback of less than 11.8 years.

<b>Life Cycle Cost Analysis</b>		<b>BEST</b>		
Alternative	Baseline	Alt. 1	Alt. 2	
Energy Use Intensity (kBtu/sq.ft)	#DIV/0!	#DIV/0!		
1st Construction Costs	\$ -	\$ 600	\$ -	
PV of Capital Costs	\$ -	\$ 1,481	\$ -	
PV of Maintenance Costs	\$ -	\$ 272	\$ -	
PV of Utility Costs	\$ 44,741	\$ 43,561	\$ -	
<b>Total Life Cycle Cost (LCC)</b>	<b>\$ 44,741</b>	<b>\$ 45,314</b>	<b>\$ -</b>	
<b>Net Present Savings (NPS)</b>	<b>N/A</b>	<b>\$ (573)</b>	<b>\$ -</b>	

Societal LCC takes into consideration the social cost of carbon dioxide emissions caused by operational energy consumption

<b>(GHG) Social Life Cycle Cost</b>		<b>BEST</b>		
GHG Impact from Utility Consumption	Baseline	Alt. 1	Alt. 2	
Tons of CO2e over Study Period	348	338	-	
% CO2e Reduction vs. Baseline	N/A	3%	103%	
Present Social Cost of Carbon (SCC)	\$ 22,085	\$ 21,474	\$ -	
<b>Total LCC with SCC</b>	<b>\$ 66,826</b>	<b>\$ 66,788</b>	<b>\$ -</b>	
<b>NPS with SCC</b>	<b>N/A</b>	<b>\$ 38</b>	<b>\$ -</b>	

**Exterior Building Grounds Lighting, Proposal 21-GP1-204:** Modifies WAC 51-11C-405061, Section C405.5.1

**Brief Description:** Reduction of the efficacy threshold for exterior lighting, with removal of redundancy in exterior lighting efficacy/controls requirement. This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Purpose of Change:** With LED sources being dominant, the wattage requirement threshold can be reduced from 50 W to 25 W without much impact. LED fixtures are the dominant light source, and the efficacy is better than other sources and the wattage of many LED fixtures in exterior applications is below 50 W. Reducing from 50 W to 25 W is staying consistent with the original intent of the requirement.

**Review Process:** The proposed change was reviewed at two TAG meetings, but changes were minor and only editorial in nature. The change in wattage was supported through the discussions.

**Probable benefits vs. probable costs:** The estimate of annual energy savings is 0.109 kWh per square foot, with little or no additional cost. Assumes 4,380 hours of operation as the lower wattage fixture is not required to be connected to an occupancy sensor. 25 W x 4,380 hours and assumed to light 1,000 square feet of space.

---

**Exterior Lighting, Proposal 21-GP1-198:** C405.5.3: Modifies Tables C405.5.3(2) and C405.5.3(3) in WAC 51-11C-405064

**Brief Description:** Updates the exterior lighting tables in response to changes in technology, with an approximate 40 percent reduction across the board.

**Purpose of Change:** Reduces exterior lighting values (last updated in 2016) in response to changes in technology. Changes the metric from footprint to gross floor area in most cases.

The values in the table have not been updated since 2016. As of 2016, LED technology was relatively new, and the efficacy was around 82 lumens per Watt. As of 2021, exterior LEDs are easily 105 lumens per Watt and many exceed 120 lm/W. In 2016, light loss factors for LEDs were somewhat an unknown. As of 2021, the lighting industry's knowledge is deeper and different light loss factors are used now. These values are change in available lighting technology as well as informed design practices.

This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Review Process:** The TAG discussed this proposal at two meetings. There were no opponents to the proposal at either meeting, and there was stated agreement that the update is a good idea. There was some discussion at how the new table values were reached. The proponent stated they took into account a 25 to 35 percent efficiency gain in LED technology coupled with new data that shows less depreciation over time.

**Probable benefits vs. probable costs:** Limited economic impact on building owners, tenants, and business.

These values are slightly greater than California's Title 24 which had an economic analysis and were deemed cost effective. These values are similar to a draft addendum of ANSI/ASHRAE/IES Standard 90.1. BC Hydro funded some cost analysis for the 90.1 proposal. Other than exchange rate, the cost of lighting equipment in Canada and US is the same. BC Hydro's lighting subcontractor provided a cost analysis and cost data of the 90.1 addendum indicating that 2021 is equipment is similar cost of 2016 equipment, but the efficacy had an increased over the period of time.

This proposal is similar to other energy code changes that involved cost analyses and those cost requirements were met.

Estimate of annual energy savings: 0.08 kWh per square foot.

Assumed at 30,000 square foot parking lot. The LPD reduced is reduced by 40% between the existing (0.06 W/ft<sup>2</sup>) and new value (0.037 W/ft<sup>2</sup>). The values in the table are roughly a 40% reduction across the board. Assumes 2,230 kWh saved.  $2,230 \text{ kWh} / 30,000 = 0.076 \text{ kWh} / \text{ft}^2$

---

**Additional energy efficiency, Proposal 21-GP1-146:** Modifies Section C406.1 in WAC 51-11C-4600

**Brief Description:** Increases the required number of energy efficiency credits to be achieved.

**Purpose of Change:** The requirements were increased approximately 16 percent, if the heat pump water heating proposal is adopted, and by approximately 33 percent if it is not.

This proposal aligns with state policy to increase energy efficiency by 70 percent by 2031.

**Review Process:** This proposal, and the restructuring of C406, were highly debated throughout the TAG meetings. This was one of the last proposals addressed, to take into account other proposed changes to the code and the efficiency gains already achieved. The final recommendation is at a lower increase than that originally proposed, with a yet lower level recommended if the heat pump water heating proposal is ultimately adopted.

**Probable benefits vs. probable costs:** The cost will vary greatly depending on the type of building and the measures selected. Not all measures are appropriate for all building types. Energy Efficiency: There will be some variation here as well, since not all building types have the same credit requirements. However, the average credit increase is 8, with each point corresponding to a 0.1 percent carbon reduction for an average 0.8 percent reduction.

---

**Load management credits Proposal 21-GP1-206:** New section WAC 51-11C-40630

**Brief Description:** Adds load management requirements for new buildings to prepare buildings to interact efficiently with the evolving electrical grid in the future.

**Purpose of Change:** The load management credit requirements are the lesser of HVAC or lighting peak shedding controls. The purpose for adding the load management requirement is to encourage reducing and shifting building load in conjunction with increasing building efficiency. Load shifting measures require installing communication controls and programming to automatically reduce electric energy use during high demand periods. Thus, the load management credits take into account the time-sensitive value of efficiency and the ability to optimize energy use for grid services. It supports the state's objective to reduce building carbon emissions and will "future proof" buildings so they can respond to changing grid needs over time. The measure savings and corresponding credit values are based on electricity cost savings determined using the ASHRAE 90.-1 time-of-use rate, which was incorporated in the ASHRAE 90.1-2022 Work Plan as an optional rate to use to demonstrate the cost effectiveness of new code change proposals involving demand flexibility measures. Utilization of this representative US TOU rate, which results in similar annual electricity costs as the average national blended rate, is intended to serve as a proxy for valuing reduced grid impact, which accommodates increases in PV, regional growth, and other grid changes impacting peak periods over time.

**Review Process:** This proposal contains more than just the load management changes, but the load management portion is where there is an economic impact. This, along with the rest of the changes to Section C406, was heavily debated and revised and revisited a number of times to ultimately be proposed to moved forward to public hearing.

**Probable benefits vs. probable costs:** Range from \$19,900 for a 240,000 sf hospital to \$453 for a 5,000 sf office or restaurant, with simple payback ranging from 1.1 year (restaurant) to 25.0 years (warehouse), with a 3.66 year statistical average. Demand responsive lighting controls cost approximately \$0.0825 per square foot. Energy Savings: Annual energy savings ranged from \$5,700 for the hospital to \$117 for the 5,000 sf office, with the statistical average of a 3.66 year payback.

The required load management credits are the lessor of either lighting control or HVAC setback/setup control during peak periods. HVAC time shift control is evaluated for cost effectiveness with the following results:

Load Management Credit Cost Effectiveness Calculation  
Demand responsive HVAC Measure

	Floor Area	DR connectivity incremental cost	Annual Energy Cost Savings (\$/year)	Simple Payback (years)
ApartmentMidRise	33,741	\$ 2,780	\$ 736	3.8
Hospital	241,501	\$ 19,900	\$ 5,718	3.5
HotelSmall	43,202	\$ 3,560	\$ 1,181	3.0
OfficeMedium	53,628	\$ 4,419	\$ 2,146	2.1
OfficeSmall	5,503	\$ 453	\$ 117	3.9
RestaurantSitDown	5,502	\$ 453	\$ 416	1.1
RetailStripmall	22,500	\$ 1,854	\$ 342	5.4
SchoolPrimary	73,959	\$ 6,094	\$ 1,552	3.9
Warehouse	52,045	\$ 4,289	\$ 172	25.0

Reference: Codes and Standards Enhancement (CASE) Initiative 2022 California Energy Code, Nonresidential Grid Integration, Final CASE Report, August 2020

Demand Responsive Lighting – incremental costs per 10,000 sq. ft.

- 1) Connected Controls with Native OpenADR VEN => \$823
- 2) Piecemeal Connected Control System with Non-Native OpenADR VEN => \$826

Estimated annual energy savings: \$0.0823 per square foot

Load Management Credit Cost Effectiveness Calculation  
Demand responsive HVAC Measure

	Floor Area	DR connectivity incremental cost	Annual Energy Cost Savings (\$/year)	Simple Payback (years)
ApartmentMidRise	33,741	\$ 2,780	\$ 736	3.8
Hospital	241,501	\$ 19,900	\$ 5,718	3.5
HotelSmall	43,202	\$ 3,560	\$ 1,181	3.0
OfficeMedium	53,628	\$ 4,419	\$ 2,146	2.1
OfficeSmall	5,503	\$ 453	\$ 117	3.9
RestaurantSitDown	5,502	\$ 453	\$ 416	1.1
RetailStripmall	22,500	\$ 1,854	\$ 342	5.4
SchoolPrimary	73,959	\$ 6,094	\$ 1,552	3.9
Warehouse	52,045	\$ 4,289	\$ 172	25.0

Reference: Codes and Standards Enhancement (CASE) Initiative 2022 California Energy Code, Nonresidential Grid Integration, Final CASE Report, August 2020

Demand Responsive Lighting – incremental costs per 10,000 sq. ft.

- 1) Connected Controls with Native OpenADR VEN => \$823
- 2) Piecemeal Connected Control System with Non-Native OpenADR VEN => \$826