

The values in this alternate table are the WA values multiplied by 1.1 (rounded to nearest whole number), except for those highlighted in yellow, which are clearly not related to fossil fuel use.

TABLE C406.2(FF)
EFFICIENCY MEASURE CREDITS for use with FOSSIL FUEL COMPLIANCE PATH

Measure Title	Applicable Section	Occupancy Group					
		Group R-1	Group R-2	Group B	Group E	Group M	All Other
1. Dwelling unit HVAC control	C406.2.1	NA	8	NA	NA	NA	NA
2. Improved HVAC TSPR ^a	C406.2.2.1	NA	9	12	19	24	NA
3. Improve cooling and fan efficiency	C406.2.2.2	2	2	3	4	3	2
4. Improve heating efficiency	C406.2.2.3	2	3	3	11	18	8
5. Improved low-carbon district energy system (10% better)	C406.2.2.4	3	3	4	12	19	9
6. Improved low-carbon district energy system (20% better) ^b	C406.2.2.5	10	11	13	36	57	26
7. High performance DOAS	C406.2.2.6	34	34	23	43	44	23/ (A) 40 ^c
8. Fault detection & diagnostics (FDD)	C406.2.2.7	2	2	2	6	9	4
9. 10% reduced lighting power	C406.2.3.1	7	4	18	16	20	15
10. 20% reduced lighting power ^d	C406.2.3.2	13	8	36	32	40	29
11. Lamp efficacy improvement	C406.2.3.3	5	6	NA	NA	NA	NA
12. Residential lighting control	C406.2.4.1	NA	8	NA	NA	NA	NA
13. Enhanced lighting control	C406.2.4.2	1	1	6	6	11	6
14. Renewable energy	C406.2.5	7	12	13	13	10	11
15. Shower drain heat recovery	C406.2.6.1	10	33	NA	3	NA	NA
16. Service water heat recovery	C406.2.6.2	35	111	13	14	(Grocery) 41 ^e	NA
17. Heat pump water heating	C406.2.6.3	81	261	17	33	(Grocery) 95 ^e	(A-2) 95 ^f
18. Heat trace system	C406.2.7.1	6	13	4	1	NA	6
19. Point of use water heater	C406.2.7.2	NA	NA	19	5	NA	NA

Measure Title	Applicable Section	Occupancy Group					
		Group R-1	Group R-2	Group B	Group E	Group M	All Other
20. Service hot water distribution right sizing	C406.2.8	13	42	NA	NA	NA	NA
21. High performance service hot water temperature maintenance system	C406.2.9	6	13	4	1	NA	6
22. High efficiency service hot water circulation system	C406.2.10	3	6	2	1	NA	4
23. Low flow residential showerheads	C406.2.11	3	3	NA	NA	NA	NA
24. Enhanced envelope performance ⁹	C406.2.12	24	20	13	5	19	14
25. Base reduced air leakage ⁹	C406.2.13.2	29	24	6	3	9	11
26. Enhanced reduced air leakage ⁹	C406.2.13.3	53	44	11	5	16	20
27. Enhanced commercial kitchen equipment	C406.2.14	30 ^h	18 ^h	18 ^h	30 ^h	30 ^h	31 ^h
28. Enhanced residential kitchen equipment	C406.2.15	12	19	NA	NA	NA	NA
29. Enhanced residential laundry equipment	C406.2.16	NA	6	NA	NA	NA	NA
30. Heat pump clothes dryers	C406.2.17	6	6	NA	NA	NA	NA
31. Efficient elevator equipment	C406.2.18	3	5	5	5	4	4